

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/SZ/ 202

Dated: 10/3 /2021

FIRE SAFETY CERTIFICATE

Certified that the Rani Jhansi Sarvodaya Kanya Vidyalaya (ID-1925031) located at Railway Colony, Tughlakabad, New Delhi-110044 comprised of Old Block-Ground & 2 Upper Floors (02Blocks+01 assembly hall) and New Block-Ground & 3 Upper Floors (2 blocks) owned / occupied by Sarvodaya Kanya Vidyalaya has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2017/SZ/1496 dated 16/10/2017. The premises was re-inspected by the officer concerned of Fire Service on 25/02/2021 in the presence of Smt. Manisha Vaish (HOS) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied old blocks with Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and the new school blocks in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy "Educational" (Group-B) with effect from 10/3 /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 10/3/21 at New Delhi by.


(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. The Principal, Rani Jhansi Sarvodaya Kanya Vidyalaya (ID-1925031) located at Railway Colony, Tughlakabad, New Delhi-110044.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Rani Jhansi Sarvodaya Kanya Vidyalaya
(ID-1925031), Railway Colony, Tughlakabad, New Delhi-110044.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC No. F6/DFS/MS/School/2017/SZ/1496 dated 16/10/2017
5. Fire Safety directives Letter No. : D.O.E. Circular Dated 01/03/2011
6. Date of inspection : 25/02/2021
7. Name of the Inspecting Officer : A.D.O. (S.J.)
8. Name and designation of Officer
from the building side : Smt. Manisha Vaish(HOS)
9. Year of Construction : Old Block-Before 1990 & New Block-2016
10. Applicant's letter No. : RJSKV/2021/252 dated 02/02/2021

Old Block-Ground & 2 Upper Floors (2Blocks)
New Block-Ground & 3 Upper Floors (2 blocks)

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. 2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Old Blk-2nos (each) New Blk.1-4nos New Blk.2-3nos	Old Blk-2nos (each) New Blk.1-4nos New Blk.2-3nos	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 m / 0.75 m 1.50 m	Old Blk-1.30m (each) New Blk.1-1.55m (each) New Blk.2-1.55m (each)	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	b. No of continuous staircase to terrace	Required	One in each block	MR
	c. Width Of Corridor	NR	NR	NR
	d. Door Size	1.00m	1.00m	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NR	NR
	• Upper floors	12 a/c per hour	NR	NR
5.	Fire Extinguishers			
	• Total numbers	45	48	MR
	• Types	ABC /Co ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

6. First - Aid Hose Reels				
	• Total numbers on each floor	Old Blk-1nos (each) New Blk.4 & 3nos	Old Blk-1nos (each) New Blk.4 & 3nos	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7. Automatic fire detection and alarming system				
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10. Automatic Sprinkler System				
	• Basements	NR	NR	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11. Internal Hydrants				
	• Size of riser/down-comer	NR	NR	NR
	• Number of hydrants per floor	NR	NR	NR
	• Hose Box	NR	NR	NR
12. Yard Hydrants				
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13. Pumping Arrangements				
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450LPM each blk.	450 LPM x 2 (each)	MR
	➤ Head of the pump	40 MH (each)	40 MH (each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
4. Captive water Storage for fire fighting				
	• Under ground tank capacity	NR	NR	NR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

Note:- General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring:- Conduit Wiring MCB and ELCB.....
Electric circuit:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2017/SZ/1496 dated 16/10/2017 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
26/02/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

[Signature]
DO(SD)

[Signature]
01/03

[Signature]
DCFO (S2)

[Signature]
F.T. Khan.