

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2021/WZ/ *Petrol/155*

Dated: *05/03/2021*

FIRE SAFETY CERTIFICATE

Certified that the Shaheed Sumeet Roy Enterprises (Dealer : Indian Oil Corporation Ltd.) located at Sector-24, Rohini, Delhi-110085, comprised of **Ground floor only** owned / occupied by Shaheed Sumeet Roy Enterprises has already been issued FSC by this department vide letter No. F.6/DFS/MS/2018/Petrol/852 dated 26.04.2018. The premises was re-inspected by the officer concerned of this department on **26.10.2021** in the presence of **Sh. Sandeep (supervisor)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class '**Hazardous (Group-J)** 40 K.L Class 'A' & 70 K.L Class 'B' with effect from *05/03/2021* for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *05/03/2021*..... at New Delhi by

[Signature]
(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to :-

1. Authorized Signatory, Shaheed Sumeet Roy Enterprises (Dealer : Indian Oil Corporation Ltd.) located at Sector-24, Rohini, Delhi-110085.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year in Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Shaheed Sumeet Roy Enterprises, Sector-24, Rohini, Delhi.
2. Type of Occupancy : Group J Hazardous Building **(Ground Floor Only)**
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2018/Petrol/852 dated 26.04.2018
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 26.02.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Sandeep (supervisor)
9. Year of Construction : 2000
10. Applicant's letter No. : Online e-mail dated 22.11.2020 .

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|--------------------------------|---------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | Accessible | 28m | MR |
| | • Gate width | Accessible | Accessible directly | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | NA | NA | NA |
| | Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.0m | 1.0m | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | NA | NA |
| | • Upper floors | 12 a/c per hour | Natural ventilation | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 02 foam of 9 ltr+ 01 Co2-4.5kg | 16 | MR |
| | • Types | ABC/CO2 | ABC/CO2 | MR |
| | • IS marking | ISI marked | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | NA | NA | NA |
| | • Ground & Upper Floors | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | NA | NA | NA |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual Stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | NA | NA | NA |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15. | Exit Signage. | NA | NA | NA |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |

Special Fire Protection System for Protection of special Risks, if any:

Fire buckets filled with sand, no smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen premises.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2018/Petrol/852 dated 26.04.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
11/3/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

Ajay
02/03/2021

Dy CPO (W2)

Ajay
26/3/2021

~~ADO~~/Rohini

FT letter is put up for kind perusal
and signature please

~~PCPO~~ (W2)

Ajay
4/3/2021

Ajay
4/3/21

MS/ cell