

c-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2021/NDZI 200


Dated: 10/3/21

FIRE SAFETY CERTIFICATE

Certified that the St. Eknath Govt. Sarvodaya Kanya Vidyalaya at J & K Block, Dilshad Garden, Delhi-110095, comprised of ground plus three upper floors (Old Building blocks), owned/occupied by St. Eknath Govt. Sarvodaya Kanya Vidyalaya was issued FSC vide letter No.F6/DFS/MS/School/2013/296 dated 15/05/13 (Old Building blocks). The school building was re-inspected by the officer concerned of this department in the presence of Mr. Nawab Singh, Estate Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy Group B "Educational Building" for ground plus three upper floor with effect from 10/3/21..... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions, printed overleaf.

Note:- This Fire Safety Certificate does not cover the New building blocks for which shortcomings were issued earlier vide letter No. F6/DFS/MS/School/2018/2361 dated 29/05/2018.

Issued on 10/3/21..... at New Delhi by


9/3/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer

To,

The Manager,
St. Eknath Govt. Sarvodaya Kanya Vidyalaya,
J & K Block, Dilshad Garden,
Delhi-110095.

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

ok 

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : St. Eknath Govt. Sarvodaya Kanya Vidyalaya, J& K Block, Dilshad Garden, Delhi-110095
2. Building is comprised of : Ground plus three upper Floors (Old Building)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2013/296 dated 15/05/13
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 24/02/21
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer from the building side : Mr. Nawab Singh (Estate Manager)
10. Year of Construction : 1990, New Building 2007
11. Applicant's letter No : E-mail Dated 11/02/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	18 mtr.	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr.	1.50 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos	2 nos	MR
	e. Width of Corridor	1.50 mtr.	02 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	15 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos	02 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr.	MR
	• Nozzle diameter	5 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
		40 mtr	Provided	MR
	• Head of the pump	Required	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump			
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.
 Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rule, it is recommended to issue Fire Safety Certificate.

Mehmood
 27/2/2021

Signature of the Inspecting Officer
 Name :- Mehmood
 Designation :- A.D.O (T.Pur)

DO(ED) *[Signature]*
 113

DY. CFO/ND 7

[Signature]
 4/3/21

DO(ED) F.E. letter is prepared and put up for sanction

DY CFO/ND 2

[Signature]
 9/3/21

[Signature]
 SB

M.S Cell

