

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No.F.6 DFS/MS/School/2021/SZ/ 193

Dated: 08 / 03 / 2021

FIRE SAFETY CERTIFICATE

Certified that The Shri Ram School located at D-3, Street, Vasant Vihar, New Delhi-110057 comprised of basement, Ground plus two upper floors (01 block) and ground plus 03 upper floors(01 block) was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/329 Dated 27/02/2018. The said premises was re-inspected by officer concerned of this department on 02/03/2021 in the presence of Sh. Chitra Singh and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "Educational Building Group - B" with effect from 08 / 03 / 2021 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 08 / 03 / 2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service
etc

Copy to: -

1. The Principal, The Shri Ram School located at D-3, Street, Vasant Vihar, New Delhi-110057
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

n/23

INSPECTION REPORT

1	Name & Address of the Building	The Shri Ram School, D-3, Street Vasant Vihar, New Delhi 110057.		
2	Type of Occupancy	Educational Building		
3	Building Comprised of	One Side (B+G+2) & Other side (G+3) interconnected block		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/329 Dated 27/02/2017		
6	Fire Safety Directives Letter No	DOE Circular dated 17/01/2005		
7	Date of Inspection	02-03-2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Chitra Singh		
10	Year of construction	1995		
11	Applicant letter No.	Gmail Dated 10/12/2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular dt 17/01/2005	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02	Provided	M/R
	➤ Basement floor.	02	Provided	M/R
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	1.50 mtr each	M/R
	➤ Basement floor	1.50m	1.50m each	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	1.50m	1.50 mtr	MR
	f) Door size	01 m	01 m	M/R
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	ISI mark	30 Nos-	MR
	• Types		ABC & CO2	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	02 at each	Provided	M/R
	• Length of hose-reel hose.	30 m	Provided	M/R
	• Nozzle Diameter	5 mm	Provided	M/R
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> • Alternate source of power • Hooter's location 	-NA-	-NA-	-NA-
8	MOEFA	-NA-	NA	-NA-
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> • Size of Riser/Down-comer • Number of Hydrant per floor • Hose box. 	-NA-	100 mm	-NA-
		-NA-	02 Nos	-NA-
		-NA-	02 Nos	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants. • Hose box. 	-NA-	07nos	-NA-
		-NA-	07 nos	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. 	-NA-	900 LPM	-NA-
		-NA-	40 m	-NA-
		-NA-	One	-NA-
		-NA-	180 LPM	-NA-
		-NA-	40	-NA-
		-NA-	900 KPM	-NA-
		-NA-	40 m	-NA-
		-NA-	Provided	-NA-
	<ul style="list-style-type: none"> • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	450 LPM	Provided	MR
		40 mtr	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	-NA-	50,000 ltr	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		5,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	Provided	-NA-
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/25


20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-
-----	--	------

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules.


Further, the management of school has complied the observations issued and communicated by this department letter of even no 30 dated 14.01.2021 and an compliance letter dated 4.03.2021 is endorsed at c/42 for ready reference.


Hence, the case for the renewal of Fire Safety Certificate under the provision of Rule 37 of Delhi Fire Service Rules, 2010 is recommended.


Accordingly, DFA is put up for approval and signature please


5/5/2021

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)


DQSD -


06/03


DCFO(SF)


4/3

M.S - 