

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2021/194

Dated: 08/03/2021

FIRE SAFETY CERTIFICATE

Certified that the **Vidya Jyoti Memorial School**, Located at **WZ-1272, Rani Bagh, Delhi-110034**, comprised of **Ground + 03 Upper Floors** was issued FSC by this department Vide Letter No.F6/DFS/MS/2018/WZ/381 dated 09.03.2018. The said premises was re-inspected by the officer concerned of this department on 01.03.2021 in the presence of **Ms. Neeta Kumari (Principal) & Sh. S.P. Chhibber (Chairman)** and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Circular No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 08/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 08/03/2021 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Principal, Vidya Jyoti Memorial School, Located at WZ-1272, Rani Bagh, Delhi-110034.
2. Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

2. Type of Occupancy : Educational Total one Blocks(Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/WZ/381 dated 09.03.2018
5. Fire Safety directives Letter No. : DOE circular 262-362 dated 17-01-2005
6. Date of inspection : 01.03.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Neeta Kumari (Principal) & Sh. S.P. Chhibber (Chairman)
9. Year of Construction : 1987
10. Applicant's letter No. : VJMS/2021 Dated Nil

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.262-362 dated 17-1-05/ letter dated 09.03.2018 | Provided at site | Remarks MR/NMR |
|------|--|--|---|------------------------------|
| 1. | Access of building | | | |
| | <ul style="list-style-type: none"> • Road width | Accessible | Provided(Accessible for small Tender with one length hose) | Old case |
| | <ul style="list-style-type: none"> • Gate width | Accessible | Old case | Old case |
| | <ul style="list-style-type: none"> • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors | 2 | Provided | MR |
| | <ul style="list-style-type: none"> • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors | 1.5mtrs | 1xvaries from 72cm to 92cm & 1x63cm | MR Old case |
| | <ul style="list-style-type: none"> • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 1 | Provided | MR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 1mtr | Provided (Including door frame) | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Rating of shaft door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Water Curtain | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements | NA | NA | NA |
| | <ul style="list-style-type: none"> • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | 8nos. | Provided | MR |
| | <ul style="list-style-type: none"> • Types | ABC & CO ₂ | Provided | MR |
| | <ul style="list-style-type: none"> • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor | 1 | Provided | MR |

| | | | | |
|-----|--|----------|----------|----|
| 7. | Automatic fire detection and alarming | NA | NA | NA |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down-comer | NA | Provided | NA |
| | • Number of hydrants per floor | NA | Provided | NA |
| | • Hose Box | NA | Provided | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | NA | NA | NA |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 lpm | Provided | MR |
| | ➤ Head of the pump | 40Mtr | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 5,000Ltr | Provided | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |

| | | | |
|--|----|----|----|
| 20. Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|--|----|----|----|

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2018/WZ/381 dated 09.03.2018 is recommended under rules 37 of the Delhi Fire Service Rules 2010 under the DFS Act 2007.

S.P. Bhardwaj
 S.P. Bhardwaj
 ADO (WP)
 11/3/21

~~SO/went~~

~~01/03/2021~~

~~DFS (W2)~~

~~21/8/2021~~

~~AD/wf~~

FT for Sopnath Jhu

~~Defor/went~~

~~8/2/2021~~

~~21/3/21~~

~~ms/cell~~

D.O. (WEST)/...96
 DATED. 1/3/2021