

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No. F.6/DFS/MS/GH/2021/SZ/ 135

Dated: 12/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that **M/s V. M. Residency Guest House** located at **50, Main Road, Massood Pur, New Delhi 110070**, comprised of basement, (Vacant), ground floor (HDFC Bank), First floor (08 Guest Room) Second Floor (05 Guest Room), Top Floor (vacant), total 13 Guest Rooms, was already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2017/SZ/1089 dated 25/07/2017. The premise was re-inspected by the officer concerned of this department on 18/02/2021 in the presence of Sh. Sulekh Malik and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential & Lodging, Group-A**" (Guest House) with effect from the date of issue 12/03/2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 12/03/2021 at New Delhi by



**(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service**

Copy to: -



1. The Manager, M/s V. M. Residency, Guest House situated at 50, Main Road, Massood Pur, New Delhi-110070.
2. The Addl. Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (i) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. The provision's under clause 7.31 of UBBL-2016 shall be done in the building on or before 31/03/2021 in compliance to the notification dated 27/05/2019 an as approved and extended the deadline for compliance time limit by the Hon'ble Minister (UD) vide letter No F5 (189)/AD/ LB/2016/710-725 dated 17/12/2020

- 1 Name & address of the building : M/s Hotel V. M. Residency, FF & SF situated at 50, Main Road, Massood Pur, New Delhi-110070..
- 2 Type of Occupancy : Residential (A-4)
- 3 Type of Case : Renewal (B+G+03 upper floor) **Guest House on FF+SF**
- 4 Details of previous NOC : F6/DFS/MS/GH/2017/SZ/1089 dated :25.07.2017
- 5 Fire Safety directives letter No : NBC Part- IV
- 6 Date of inspection : 18.02.2021
- 7 Name of the Inspecting Officers : ADO (BCP) Rajesh Kumar
- 8 Name and designation of officers : Sh. Sulekh Malik  
from the building side
9. Year of Construction : 2011
10. Applicant's letter No. : No. Nil Dated: 19.01.2021

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	01	01	MR
	b. Width of staircases			
	• Upper Floors	1.25m	1.25m	MR(old case)
	• Basements	1.25m	1.25m	MR(old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	06nos	07nos	MR
		ABC & Co2	06- ABC & 01-Co2	MR
		Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	01	MR
		30 m	30 m	MR
		5mm	5mm	MR
7	<b>Automatic fire detection and alarming system. Circular date 17/12/2020 amendment / modification in (UBBL-2016 till 31/03/2021)</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	Less than 200m <sup>2</sup>	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	100mm	NA
		NA	01	NA
		NA	01	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		30m	30m	MR
		NA	NA	NA


	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	10,000ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the premises were checked, tested at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 1291 dated 08/12/2020

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/GH/2017/SZ/1089 dated 25/07/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: - Rajesh Kumar  
 Designation: - ADO/BCP

F.I.P please  
 King  
 22/02

Dated, 22/02/2021