

621

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F6/DFS/MS/School/NDZ/2021/ 224

Dated: 12/03/2021

FIRE SAFETY CERTIFICATE

Certified that the **Ramjas Sr. Sec. School No. 1**, located at **Daryaganj, New Delhi-02**, comprised of **ground plus + 1 upper floor** was granted Fire Safety Certificate by this department vide letter No-F6/DFS/MS/School/2018/309 dated 27.02.2018. The school building was re-inspected by Assistant Divisional Officer (SPM) from this department on 09.03.2021 in the presence of Mr. Rajesh Sansanwal (HOS) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. 3298 to 3398 dated 01.03.2011 issued by the Director of Education and the building (**Ground floor + 01 upper floor only**) is fit for occupancy of Group B "Educational Building" with effect from 12/03/2021 renewed for a period of three years, subject to conditions printed below.

Issued on 12/03/2021 at New Delhi by


11/3/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

1. The Principal
Ramjas Sr. Sec. School No. 1, located at **Daryaganj, New Delhi-02**
2. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi

e/c D.K.
11/3

Condition for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/10

INSPECTION REPORT

1	Name & address of the building	Ramjas Sr. Sec. School No. 1, located at Daryaganj, New Delhi-02		
2	Building is comprised of	Ground + 1 upper floor		
3	Type of Occupancy	Group B –Educational Building		
4	Type of Case	Renewal		
5	Details of Previous FSC	F6/DFS/MS/School/2018/309 dated 27.02.2018		
6	Fire Safety direction letter No	Directorate of Education Circular no. 3298 to 3398 dated 01.03.2011		
7	Date of Inspection	09.03.2021		
8	Name of the Inspecting Officers	Rajesh Kumar Shukla ADO (SPM)		
9	Name of the designation of Officer from the building side	Mr. Rajesh Sansanwal (HOS)		
10	Year of Construction	1912		
11	Applicant's letter No	Email dated 23.02.2021		
S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 dated 01.03.2011	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	06 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	A. Number of Staircases			
	Upper Floor	01 no.	02 no.	MR
	Basement	NA	NA	NA
	B. Width of Staircases			
	Upper Floor	1.5 m	1.7 m & 0.75 m	MR(old case)
	Basement	NA	NA	NA
	C. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	D. No. of continuous staircases to terrace	NA	NA	NA
	E. Width of Corridor	NA	NA	NA
	G. Door size	1 m	1m	MR
3	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	Basement	30a/c per hour	NA	NA
	Upper floor	12 a/c per hour	NA	NA

2/11

5.	Fire Extinguisher			
	Total numbers	12 no.	12 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA

2/11

2/12

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any: fire Buckets			MR

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter No. F6/DFS/MS/School/2018/309 dated 27.02.2018 is recommended to be renewed.

R.K.
11/03/2021

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CD)

R.K.
9/3

Dy. CD (NA2)

R.K. Shukla
10/3/21

ADO (SPM) F? is put up for signatures ple

R.K.
11/03/21

Dy. CD (NA2)

R.K. Shukla
11/3/21

