

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2021/ S2/EH/20

Dated: 16/03/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Domino's Pizza India, Shop No.-102A, **First Floor**, Multi Level Parking cum Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-110023 in a building comprising Basement, Ground Floor & 8 Upper Floors only owned / occupied by M/s Jubilant Food Works Ltd. (Domino's Pizza), have complied with the Fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 02/03/2021 in the presence of Miss. Aarti (Shift Manager) and found that the building / premises is fit for the occupancy class "Assembly" (Eating House) **(First Floor Only)** with effect from 16/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/03/2021 at New Delhi by.


(ATUL GARG)
DIRECTOR.

Copy to:

1. Mr. Mohd Danish Siddiqui, M/s Domino's Pizza India, Shop No.-102A, FF, Multi Level Parking cum Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-23.
2. Joint. Commissioner of Police, Licensing Unit, 1st Floor, Defence Colony, New Delhi-110049.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

Total covered area of the restaurant at the ground floor is 137.9m² and as per NBC (Part-IV) the no. of occupants comes out to be Approx. 77 (137.9/1.8=76.61). Thus capacity of restaurant is 77 persons which is covered under DFS Act 2007, Rules 2010. Subsequently inspection of Eating House is carried out as per NBC (Part-IV).

1. Name & address of the building: **M/s Domino's Pizza India, Shop No.-102A, FF, Multi Level Parking cum Commercial Complex (MLCP), DLF South Square Mall, Sarojni Nagar, New Delhi-110023.**
2. Type of Occupancy : **Assembly (E/H)**
3. Building Comprised of : **Basement, Ground & 8 Upper Floors only but eating house is running only First Floor only.**
4. Type of Case : **New**
5. Details of previous NOC : **Nil (F6/DFS/MS/Mixed/SZ/2018/2140 dated 19/09/2018 for Mall)**
6. Fire Safety directives Letter No. : **NBC (Part-IV)**
7. Date of inspection : **02/03/2021**
8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
9. Name and designation of Officer from the building side : **Miss. Aarti (Shift Manager)**
10. Year of Construction : **2011 & 2014**

11. Applicant's letter received through email ID-mohddanishsiddiqui72@gmail.com dated 19/02/2021


S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtr	9 mtr ✓	MR
	• Gate width	4.5m	Provided ✓	MR
	• Width of internal road	6m	Provided ✓	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	5 ✓	MR
	• Basements	N/A	N/A ✓	N/A
	b. Width of staircases			
	• Upper floors	2m & 1.50m	1.5m x 2, 1.4m, 1.2m & 1.1m	MR (Old Case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	Required	Provided ✓	MR
	f. Door Size	2.00 mtr & 1.50 mtr	2.00 mtr & 1.50mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided ✓	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided ✓	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	2	5 ✓	M/R
	• Types	ABC/CO ₂	Provided ✓	M/R
	• ISI marking	Required	Provided	M/R

	• Total numbers on each floor	1	4	MR
	• Length of hose reel hose	30 Mtr.	36 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system (Fire Fighting System is common for entire mall building)			
	• Type of detector	Smoke & Heat	Provided	MR
	• Location of Main Panel	N/A	Provided	MR
	• Location of Repeater Panel	N/A	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Ground Floor	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants (Fire Fighting System is common for entire mall building)			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	N/A	4	N/A
	• Hose Box	N/A	4	N/A
12.	Yard Hydrants (Fire Fighting System is common for entire mall building)			
	• Total number of hydrants	N/A	4	N/A
	• Hose Box	N/A	4	N/A
13.	Pumping Arrangements (Fire Fighting System is common for entire mall building)			
	• Ground Level			
	➤ Discharge of main pump	N/A	2850 LPM	N/A
	➤ Head of main pump	N/A	70m	N/A
	➤ Number of main pumps	N/A	2	N/A
	➤ Jockey pump out put	N/A	180LPM x 2	N/A
	➤ Jockey pump head	N/A	70m	N/A
	➤ Standby Pump out put	N/A	2850 LPM	N/A
	➤ Standby Pump Head	N/A	70m	N/A
	➤ Auto Starting/Manual stopping	N/A	Provided	N/A
	➤ Pump House Access	N/A	Provided	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40 MTR	40 MTR	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting (Fire Fighting System is common for entire mall building)			
	• Underground tank capacity	N/A	1,50,000 ltr	N/A
	➤ Draw of connection	N/A	Provided	N/A
	➤ Fire service inlet	N/A		


		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	Provided	N/A
	➤ Pressurization of lift lobby	N/A	Provided	N/A
	➤ Communication in lift Car	N/A	Provided	N/A
	➤ Fireman's Grounding Switch	N/A	Provided	N/A
	➤ Lift Signage	N/A	Provided	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	Provided	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	Provided	N/A
	➤ Battery backup	N/A	Provided	N/A
	➤ Building Floor Plans	N/A	Provided	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	Provided	N/A


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


3/3/2021


Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)


D.O. (SD)


24/03


DeFO (S2)


8/3


C./F.O



