

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/GH/SZ/2021/141

Dated: 16/03/2021

C-58

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Hotel Sun Star Residency located at 8A/50, WEA, Karol Bagh, New Delhi- 110005** comprised of basement (Storage), ground floor (reception, office & 02 guest rooms), first floor, second floor and third floor each having 05 guest rooms (total 17 guest rooms) and a pantry for staff with staff room on terrace floor was granted FSC by this department vide letter no. F6/DFS/MS/GH/SZ/2017/1409 dated 25.09.2017 and re-inspected by the officers concerned of this department on 02.03.2021 in presence of Sh. Anchit, manager of the guest house. The said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) for **basement (store), ground floor (reception, office & 02 guest rooms), first, second & third floor each having 05 guest rooms (total 17 guest rooms)** with effect from 16/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 16/03/2021 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Joint C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi.
2. The Manager, M/s Hotel Sun Star Residency, 8A/50, WEA, Karol Bagh, New Delhi- 110005.

**Conditions for the Validity of Fire Safety Certificate**

1. No occupancy above third floor & basement as storage purpose, shall be adhered by Owner/Occupier
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
10. Basement shall be used as per BBL.
11. No temporary shed is allowed on terrace.
12. The Fire Safety Certificate is only for Guest Rooms.
13. **The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/710-725 dated 17.12.2020 in respect of existing building (copy enclosed) shall be implemented by 31.03.2021 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void.**



1. Name & address of the building : M/s. Hotel Sun Star Residency, 8A/50, WEA, Karol Bagh, New Delhi- 110005.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2017/1409 dated 25.09.2017
5. Fire Safety directives letter No : Nil
6. Date of inspection : 02.03.2021
7. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Sh. Anchit, Manager
9. Year of Construction : 1982-83
10. Applicant's letter No. : Online Application Id 2020092307246 dated 22.02.2021

The said guest house is comprised of basement, ground plus four upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Existing fire safety requirements as per FSC dated 25.09.2017	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	01	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts	1.30 mts	MR being old case
	• Basements	1.25 mts	1.15 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	1.20 mts	MR being old case
	h. Door Size	Old case	0.80 mts	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	20	Provided	MR
	• Types	CO <sub>2</sub> , ABC, WCO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Carbon Monoxide	Not Provided	date of compliance has been extended up to 31.03.2021
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	30 mts	30 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	----
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 lts	5,000 lts	MR being o



16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	D.G. set of 85 KVA	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The management has given an undertaking not to use any occupancy above third floor & basement as storage purpose .

The fire protection systems provided in the building were checked and found functional at the time of inspection.

The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/710-725 dated 17.12.2020 in respect of existing building (copy enclosed) shall be implemented by 31.03.2021 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/SZ/2017/1409 dated 25.09.2017, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

*[Handwritten Signature]*  
3/3/21

Signature of the Inspecting Officer  
Name - P.V. Rathee  
Asstt. Div. Officer (SRD)

*D.O. (S.W.)*

*Pl. Spear about the composition of bldg. as it is not matching with no/19*

*[Handwritten Signature]*  
03/10/21/2021

*Asstt. Div. Officer (SRD)*