

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No.F6/DFS/MS/Bnqt/2021/NDZ/ 169

Dated: 15/03/2021

FIRE SAFETY CERTIFICATE

Certified that the J. B. Jashn The Banquet running on first floor of the building comprised of three basement, ground plus four upper floors at 813/1, Vikas Cine Mall, G. T. Road, Shahdara, Delhi-110032 owned/occupied by M/s J. B. Jashn The Banquet was issued FSC vide letter No. F.6/DFS/MS/Bnqt/2018/123 dated 22/01/2018. The premises was re-inspected by officer concerned of this department on 27/02/2021 in presence of Mr. Ajay Garg, Partner of the Banquet hall and found that building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules 2010 and found that the first floor of Banquet hall building is fit for occupancy Group "D" Assembly Building with effect from 15/03/2021.... for a period of **three** years, in accordance and further subject with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on... 15/03/2021 at New Delhi by


10/3/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

Mr. Ajay Garg (Partner),
M/s J. B. Jashn The Banquet,
(A unit of ARS Enterprises),
813/1, Vikas Cine Mall, G. T. Road,
Shahdara, Delhi-110032

Copy:-

The Dy. Health Officer,
East Delhi Municipal Corporation,
Health Department, Karkardooma,
North Zone, Shahdara, Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : J. B. Jashn The Banquet, 813/1, Vikas Cine Mall
G.T. Road, Shahdara, Delhi-110032
2. Building is comprised of : Three Basement and ground plus four upper floors
3. Type of Occupancy : Assembly (Banquet Hall) at first floor
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/BNQT/2018/123 Dated
22/01/2018
6. Fire Safety direction letter No. : F6/DFS/BP/2013/1790 Dated 12/07/2013
7. Date of Inspection : 27/02/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer
from the building side : Mr. Ajay Garg, Partner
10. Year of Construction : 2012
11. Applicant's letter No : Letter No. Nil, Dated 01/02/2021

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directives Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 m	39m	MR
	• Gate width	4.50 m	4.50 m	M/R
	• Width of internal road	06 m	06 m	M/R
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	05 nos.	05 nos.	MR
	• Basement	05 nos.	05 nos.+ 01 Ramp	MR
	B. Width of Staircases			
	• Upper floor	1.50 m & 2 m	1.50 m & 2 m	MR
	• Basement	1.50 m	1.50 m & 2 m	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	M/R
	• Pressurization	Required	Provided	M/R
	d. No. of Continuous Staircases to Terrace (Common with the mall building).	02 nos.	02 nos.	MR
	e. Width of Corridor	1.50 m & 2 m	1.50 m & 2 m	M/R
	f. Door Size	1 m & 2m	1 m (01 Door) & 2m (02 Door)	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	Required	Provided	M/R
	• Fire rating of shaft door	1 & 2 hrs.	Provided	M/R
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	Required	Provided	M/R
04	Smoke Management System			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	06 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC/Co2	MR
	• IS marking	ISI marked	ISI marked	MR

2/11

06	First-Aid-Hose Reels.			
	Total numbers on each floor	03 nos.	03 nos.	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	Basement	Provided	MR
	• Location of repeater panel	Security room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	Staircase	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	03 nos.	03 nos.	MR
	• Hose box	03 nos.	03 nos.	MR
12	Yard Hydrants			
	• Total number of hydrants	04 nos.	07 nos.	MR
	• Hose box	04 nos.	07 nos.	MR
13	Pumping Arrangements			
	➤ Ground Level			
	• Discharge of main pump	2850 LPM	2850 LPM	MR
	• Head of main pump	70 M	70 M	MR
	• Number of main pumps	02 nos.	02 nos.	MR
	• Jockey pump out put	180 LPM	180 LPM	MR
	• Jockey pump head	70 M	70 M	MR
	• Standby pump out put	2850 LPM	2850 LPM	MR
	• Standby pump head	70 M	70 M	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
	•			
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	2,00,000 Ltr.	2,00,000 Ltr.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltr.	20,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR

N/12

16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	Required	Provided	MR

The vikas Cine Mall Building has been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/Banquet/2019/1434 dated 12/07/2019. Most of fire prevention & fire safety measures are common with the mall building.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety measures required as per directives F.6/DFS/BP/2013/1790 dated 12/07/2013, it is recommended to renew Fire Safety Certificate under rule 37 of the Delhi Fire Service Rule 2010.

(Signature)
3/3/21
(Nagender Singh)
ADO (Shahdara)

DQ(ED) *(Signature)*
3/3/21

DY. CRO/NDZ F.G. Pl.
(Signature)
4/12/21

ADOCs(xn) FT is placed for signatures please

(Signature)
3/3

(Signature)
3/3

DQ(ED) DY. CRO/NDZ

F.G. Director

