

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2021 / Mixed / 186

Dated: 24/03/2021

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Agarsain College of Nursing** located at **Bawana Road, Narela, Delhi-110040** comprised of **Basement+Ground+Two upper floors** owned/ occupied by **Maharaja Agarsain Education Society(Regd.)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on **05.03.2021** in the presence of Sh. M.P. Singh (Administrative officer) and found that the building/ premises is fit for **occupancy Mixed 'Educational' & Residential (Hostel)** with effect from 24/03/2021 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 24/03/2021 ... at New Delhi by


(Atul Garg)
Director

Ph-011-23414000

Copy to:-

1. Maharaja Agarsain College of Nursing, Bawana Road, Narela, Delhi-110040.
2. Registrar, Delhi Nursing Council, Ahilya Bai Collage of Nursing Building, Lok Nayak Hospital, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

2. Name & address of the Applicant : Agarsain Education Society(Regd.), Bawana Road, Narela
Delhi-110040
3. Type of Occupancy : Mixed 'Educational' & Residential (Hostel)
4. Building Composition : Basement(Auditorium & Library), Ground(office & Two Labs),First Floor(6 class rooms & one lab),Second floor(Hostel -7 rooms & One dinning hall)
5. Type of Case : New Case
6. Details of Previous NOC : NIL
7. Fire Safety directives letter No : Nil
8. Date of inspection : 05/03/2021
9. Name of Inspecting Officer : DO (NW) & ADO(BW)
10. Name and designation of officers from the building side : Sh. M.P. Singh (Administrative officer)
11. Year of Construction : 2017-2018
12. Applicant's letter No. : E Mail id Dated 04/01/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	6m	No boundary wall, directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	01 Staircase & 01 Ramp	MR
	b. Width of staircases			
	• Upper Floor	1.50 m	Provided	MR
	• Basements	1.50 m	1.5m & 2m(Ramp)	MR
	c. Protection of exits			
	• Fire check door	Required in Basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.2m & 2m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided at basement	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	12 ac/hr	Exhaust fan provided	MR
	• Upper floors	12 ac/hr	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	Required	24nos	MR
	• Types	ABC	Provided	MR
	• IS marking	Required	Provided	MR

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m	Provided	MR
		05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 + 450 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000+ 5000 ltrs	10,000+10,000ltrs	MR
		Required	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR

18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Signature of Inspecting Officer
 Name:- D.B Mukharjee
 Designation:- DO(NW)

Signature of Inspecting Officer
 Name: Rajeev Kumar Sinha
 Designation; ADO(BW)

Pl specify

Signature
 09/03/2021

ADO (BW) Specimen is resubmitted please

Signature
 ADO(BW)
 15/3/2021

DO(NW)

Signature
 15/03/2021

By ADO (W2)

What about showbeam
 at C-14
 Signature
 22/3/2021

Signature
 ADO(NW)

Sir we have been given as built plan by the authorities of institute that fulfills the requirement