

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021 / 189

Dated: 26/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Industrial Building** located at **Plot No. B-51, G.T. Karnal Road, Industrial Area, Delhi-110033** comprised of **basement, ground & 02 upper floor only** owned/occupied by **M/s Ram Ram Ji Peripherals** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **23.03.2021** in presence of **Sh. D.R. Mehta (Supervisor)** of the premise is fit for occupancy class G-2 Industrial occupancy for **basement, ground & two upper floor only** with effect from.... 26/03/2021... for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 26/03/2021... at New Delhi

  
(Atul Garg)  
Director

Ph:-011-23414000

Copy to :-

1. The Authorized Signatory, Plot No. B-51, G.T. Karnal Road, Industrial Area, Delhi-110033
2. The Executive Engineer (Bldg.), HQ., NDMC, Civic Centre, Minto Road, Delhi.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : Industrial Building, Plot No. B-51, G.T.K. Road, Industrial Area, Delhi- 110033.
2. Type of Occupancy : Industrial Building
3. Type of Case : (Completion) New Case (B+G+02 upper floor)
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : F6/DFS/MS/BP/2019/419 dated 03.12.2019
6. Date of inspection : 23.03.2021 , 10 A.M.
7. Name of the Inspecting Officers : DO/NW & ADO(RN)
8. Name and designation of officers from the building side : Sh. D.R. Mehta (Supervisor)
9. Year of Construction : 2020
10. Applicant's letter No. : Completion Request Id. No-10085344 dated 16.03.2021

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL 2016	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 m	30 m	MR
	• Gate width	5.0m	12m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50mtr each	1.80m & 1.50m	MR
	• Basements	1.50m each	1.50m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	1.50 m	1.60 m	MR	
3	<b>Compartmentation</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	16 no's	18 no's	MR
	• Types	ABC/CO2	ABC/Co2	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	02at each floor	02 Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke/ Heat	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	02nos at each floor	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02 at each floor	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	05nos	06nos	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Required	Provided	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> </ul> </li> </ul>	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Head of Main pump</li> </ul> </li> </ul>	80m	80m	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Number of main pumps</li> </ul> </li> </ul>	02nos	02nos	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Jockey Pump out put</li> </ul> </li> </ul>	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Jockey pump head</li> </ul> </li> </ul>	80m	80m	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Standby Pump out put</li> </ul> </li> </ul>	2280lpm (Diesel Operative)	2280lpm (Diesel Operative)	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Standby Pump Head</li> </ul> </li> </ul>	80m	80m	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Auto Starting/ Manual stopping</li> </ul> </li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Pump House Access</li> </ul> </li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> </ul> </li> </ul>			
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Head of the pump</li> </ul> </li> </ul>	900 LPM	900 LPM	MR
	<ul style="list-style-type: none"> <li> <ul style="list-style-type: none"> <li>Power Supply</li> </ul> </li> </ul>	40m	40m	MR
		Required	Provided	MR

		Required		
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	2,00,000 ltr	2,00,000 ltrs	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltr	20,000 ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. 453 dated 25.02.2021 have been compiled by the management.

Keeping in view of satisfactory compliance of the minimum standards on fire prevention and fire safety required under the rules and fire safety guidelines issued vide letter of even no.419 dated 03.12.2019, it is recommended to issue Fire Safety Certificate.

Signature of the Inspecting Officer  
Name :-D.B. Mukherjee  
Designation:-DO/NW

Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation:- ADO/RN

Do(NW)

By CFO (W2)

FT PS

ADO RN

