

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6/DFS/MS/2021/WZ/School/ 270

Dated: 30/3 /2021

FIRE SAFETY CERTIFICATE

Certified that the **R.P.Govt. Girls & Boys Sr. Sec. School, Sec-5, Rithala, Rohini, Delhi-110085**, comprised of **Total 08 Blocks, 04Blk-Gr.+ 01 & 04 Blk-Gr. floor (Porta Cabin)** owned/occupied by **R.P.Govt. Girls & Boys Sr. Sec. School** was granted FSC by this department vide letter No. **F.6/DFS/MS/School/2018/WZ/750 dated 20.04.2018**. The premises was re-inspected by the officer concerned of this department on **10.03.2021** in the presence of **Sh. Suresh Kumar (Estate Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from30/3/21..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on30/3/21..... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, R.P.Govt. Girls & Boys Sr. Sec. School, Sec-5, Rithala, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : R.P.Govt. Girls & Boys Sr. Sec. School, Sec-5, Rithala, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Total 08 Blocks, 04 Blk-Gr. + 01 & 04 Blk-Gr. floor)
4. Details of Previous NOC : F.6/DFS/MS/School/2018/WZ/750 dated 20.04.2018
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 10.03.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Suresh Kumar (Estate Manager)
9. Year of Construction : 1964 & 2010
10. Applicant's letter No. : Letter No. RPSKV/677/Rithala dated 02.02.2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Accessible 4.0m NA 	<ul style="list-style-type: none"> MR MR (Old Case) NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 06 NA 	<ul style="list-style-type: none"> 06 NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> Bkl-I-1.50m Bkl-II-1.5m & 1.35 Bkl-III-1.50m & 1.4m Bkl-IV-1.50m NA 	<ul style="list-style-type: none"> MR (Old case) NA
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
		<ul style="list-style-type: none"> NA 1.0m 	<ul style="list-style-type: none"> NA 1.5m 1.0m double door 	<ul style="list-style-type: none"> NA NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> NA Natural ventilated 	<ul style="list-style-type: none"> NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 15nos. ABC/CO2 ISI marked 	<ul style="list-style-type: none"> 17nos ABC Yes 	<ul style="list-style-type: none"> MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA

	<ul style="list-style-type: none"> • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel 	NA	NA	NA
		NA	NA	NA

	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2018/WZ/750 dated 20.04.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
19/3/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)
Ajay
19/03/2021

Dy C/S (W2)
28/03/2021

ADO Rohini

FT letter is put up for kind perusal and
Signature please.

Dy C/S (W2)

Ajay
28/3/21

Ajay
28/3/21

MS/ self