

C/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2021/SZ/ 245

Dated: 23/03/2021

FIRE SAFETY CERTIFICATE

Certified that the South Delhi Nigam Pratibha Vidyalaya, New Chaukhandi, New Delhi-110018, comprised of ground plus two upper floors, owned/occupied by South Delhi Nigam Pratibha Vidyalaya was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2014/WZ/1100 dated 01/09/2014 (for ground floor only). The School building was re-inspected by the officer concerned of this department on 03/03/2021 in the presence of Smt. Veena Gandhi (Principal) and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 23/03/2021 at New Delhi.


(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. The Principal,
South Delhi Nigam Pratibha Vidyalaya,
New Chaukhandi, New Delhi-110018.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : South Delhi Nigam Pratibha Vidyalaya, New Chaukhandi, New Delhi-110018
2. Building is comprised of : ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : Addition/Alteration
5. Details of Previous NOC : F.6/DFS/MS/School/2014/WZ/1100 dated 01/09/14 (For ground floor only)
6. Fire Safety directives letter No : Director of Education 3298-3398 dated- 01/03/2011
7. Date of inspection : 03/03/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Veena Gandhi (Principal)
10. Year of Construction : 1980 & 2015
11. Applicant's letter No. : Nil dated 03/02/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width 	06 m	Provided	MR
	<ul style="list-style-type: none"> • Gate width 	4.5 m	Directly accessible from road	MR
	<ul style="list-style-type: none"> • Width of internal road 	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors 	02 no.'s	02 no.'s	MR
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor 	1.50 m	1.50 & 1.35 m	MR
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		2 no.	2 no.	MR
		1.50 m	1.5 m	MR
	e. Width of Corridor			
		1 m	1.12 m	MR
	f. Door Size			
		2X1.5 M	2X1.5 M	MR
	g. Hall without stage			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural Ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	07 No's	12 Nos. Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC/CO ₂ type	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	ISI marked	MR

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 no. 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	100 mm 1 no. 1 no.	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 40 m Required Required	N/A 450 LPM Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10,000 ltrs	N/A N/A N/A N/A Provided	N/A N/A N/A N/A MR
15.	Exit Signage.	Required	Provided	MR

N/15

16.	Provision of Lifts.	(No Lift)		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. Previous FSC was issued for ground floor only now become ground plus two upper floors.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2014/WZ/1100 dated 01/09/2014 (for Ground floor only) renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
12/03/2021

Signature of Inspecting Officer
Name:- R.K YADAV
Designation:- Asstt. Divisional Officer

D.O. (South West)

Kumar
12/03/2021
Dy CPO (SW)

F.t. please.
[Signature]

A O O K P

Signature please