

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No.F.6 DFS/MS/School/2021/SZ/ 273

Dated: 31 / 3 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that Modern Perfect Public School, at L-35, Khasra No- 44/19, Gali No 03, 04, Shani Bazar Road, Sangam Vihar, New Delhi- 110060 comprised of Basement and Ground floor was granted Fire Safety Certificate by this department vide letter No. F6/MS/DFS/School/2017/SZ/24 Dated 02-01-2018. The said premise was re-inspected by officer concerned of this department on 18/03/2021 in presence of Sh. Naresh Kumar (owner) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 31 / 3 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 31 / 3 / 2021 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Principal, Modern Perfect Public School, at L-35, Khasra No- 44/19, Gali No 03, 04, Shani Bazar Road, Sangam Vihar, New Delhi- 110060
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**


1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	Modern Perfect Public School, at L-35, Khasra No- 44/19, Gali No 03, 04, Shani Bazar Road, Sangam Vihar, New Delhi- 110060		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement and Ground floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2017/SZ/24 Dated 02-01-2017		
6	Fire Safety Directives Letter No	DOE Circular 01/03/2011		
7	Date of Inspection	18/03/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Naresh Kumar (owner)		
10	Year of construction	2014		
11	Applicant letter No.	Gmail dated 10/02/2021		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1.</b>	<b>Access to Building.</b>			
	• Road width	Required	6 mtr ✓	MR
	• Gate width	Required	4.5 mtr ✓	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2.</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	02 Nos	Provided	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	1.5 m / 0.75 m	1.14 m & 0.85 m	MR (old case)
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	1.50 m	Provided	MR
	<b>f) Door size</b>	1m	Provided ✓	MR
<b>3.</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	05 Nos ✓	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
<b>7.</b>	<b>Automatic fire detection &amp; alarming system.</b>			



2/14

	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	01 Co2 type fire extinguisher is provided near elect. Panel.		-NA-
<p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2017/SZ/24 Dated 02-01-2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>2018 SZ Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">             Signature of the Inspecting Officer            Name: Sh. Rajesh Kumar            Design: ADO (BCP)         </p>				

~~DO (SD)~~

DO  
22/03

DO (SD)

F. t. please



ADO (BCP)

As approved, f.t. letter is put up for your signature pl

DO  
26/3

DO (SD)



M.S. all