

418

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 266

Dated: 26/03/2021

FIRE SAFETY CERTIFICATE

Certified that the Nagar Nigam Prathmic Pratibha School at Balbir Nagar Extn., Shahdara Delhi comprised of ground plus two upper floors owned/occupied by Nagar Nigam Prathmic Pratibha Vidyalaya was issued FSC vide letter No.F.6/DFS/MS/School/2018/NDZ/529 dated 27/03/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officers concerned of this department on dated 16/03/2021 in the presence of Mrs. Sunita Singh, Principal of the school and found that the school building is fit for occupancy class "B" 'Educational Building' for ground plus two upper floors with effect from 26/03/2021.. for a period of three years, in accordance and further subject with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....26/03/2021.....at New Delhi by



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

The Principal,
Nagar Nigam Prathmic Pratibha School,
Balbir Nagar Extn., Shahdara,
Delhi

Copy:-

The Dy. Director of Education,
M.C. D. (Education Department),
Shahdara South Zone, Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

- | | |
|--|--|
| 1. Name & address of the building | : Nagar Nigam Prathmic Pratibha School,
Balbir Nagar Extn., Shahdara, Delhi-110032 |
| 2. Building is comprised of | : Ground plus two upper floors |
| 3. Type of Occupancy | : Educational |
| 4. Type of Case | : Renewal |
| 5. Details of Previous NOC letter | : F.6/DFS/MS/School/2018/NDZ/529
dated- 27/03/2018 |
| 6. Fire Safety direction letter No.
3398 | : F16/Estate/CC/Fire Safety/2011/3298 to
dated- 01/03/11 |
| 7. Date of Inspection | : 16/03/2021 |
| 8. Name of the Inspecting officers | : ADO Nagender Singh |
| 9. Name and designation of Officer
from the building side | : Mrs Sunita Singh, Principal |
| 10. Year of Construction | : 1973 & 2010 |
| 11. Applicant's email ID | : balbirnagarextention1152089@gmail.com |

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m N/A N/A	6 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	2 nos. N/A	2 nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1.50m N/A	1.50 m each N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	1 no.	01 no.	MR
	e. Width of Corridor	1.50 m	2.35 m	MR
	f. Door Size	1m	1m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 nos. ABC/CO ₂ ISI marked	12 nos. ABC/ CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	Provided	MR
09	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 X 2 LPM	MR(as accepted earlier)
	• Head of the pump	40 m	Provided	MR(as accepted earlier)
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

N/12

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested/Checked and found functional, at the time of inspection.

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required as per F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to renew FSC under rule 37 of the Delhi Fire Service Rule 2010.

(Signature)
 Nagender Singh
 ADO(Shahdara)
 18/3/21

DO(ED)
(Signature)
 18/3

DY. CFS/NDZ
 F.I. pl.
(Signature)
 18/3/21

ADO(Shahdara) FT is placed for signatures please
(Signature)
 21/3



DO: Dy. CFS(NDZ)
(Signature)
 21/3/21

M.S.CE11