


**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2021/ 226

Dated: 16/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that **Sai Public School located at WZ- 86A, Todapur Village, New Delhi- 110012**, running at ground floor only of a building comprised of ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2018/801 dated 24.04.2018 (for ground floor only). The school building was re-inspected by the officer concerned of this department on 10.03.2021 in presence of Ms. Mohan Kumar, caretaker of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 20007 and Rules 2010 and that the building/premises is fit for occupancy class "Educational" with effect from 16/03/2021 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions printed overleaf under rule 38 of the Delhi Fire Service Rules, 2010. Issued on 16/03/2021 at New Delhi by.



(Sunil Chaudhary)

Dy. CHIEF FIRE OFFICER(SZ)

Copy to: -

1. The Manager, Sai Public School, WZ- 86A, Todapur Village, New Delhi- 110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

**Conditions for the Validity of Fire Safety Certificate**

1. Main road width varies from 2.65 to 3.70 mts. but there is open space available from which fire engine can reach upto school building. It is the responsibility of owner to keep clear open space for fire engine to reach upto building. If this open space will not be available in future then FSC will stands null and void automatically.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)





|    |  |   |   |   |
|----|--|---|---|---|
|    | <ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>  | 30 a/c per hour<br>12 a/c per hour            | N/A<br>N/A                                      | N/A<br>N/A                                      |
| 5  | <b>Fire Extinguishers</b>  |   |   |   |
|    | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>   | 12 nos.<br>ABC type<br>ISI marked             | Provided<br>Provided<br>Provided                | MR<br>MR<br>MR                                  |
| 6  | <b>First-Aid Hose Reels.</b>   |   |   |   |
|    | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>   | ----<br>30 m<br>5 mm                          | N/A<br>N/A<br>N/A                               | N/A<br>N/A<br>N/A                               |
| 7  | <b>Automatic fire detection and alarming system.</b>   |   |   |   |
|    | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>  | N/A<br>N/A<br>N/A<br>N/A<br>N/A               | N/A<br>N/A<br>N/A<br>N/A<br>N/A                 | N/A<br>N/A<br>N/A<br>N/A<br>N/A                 |
| 8  | <b>MOEFA</b>   | Required                                      | Provided  | MR  |
| 9  | <b>Public Address System.</b>  | Required                                      | Provided  | MR  |
| 10 | <b>Automatic Sprinkler System</b>  |   |   |   |
|    | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>   | N/A<br>N/A<br>N/A                             | N/A<br>N/A<br>N/A                               | N/A<br>N/A<br>N/A                               |
| 11 | <b>Internal Hydrants</b>   |   |   |   |
|    | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>   | N/A<br>N/A<br>N/A                             | N/A<br>N/A<br>N/A                               | N/A<br>N/A<br>N/A                               |
| 12 | <b>Yard Hydrants.</b>  |   |   |   |
|    | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>   | N/A<br>N/A                                    | N/A<br>N/A                                      | N/A<br>N/A                                      |
| 13 | <b>Pumping Arrangements</b>  |   |   |   |
|    | <ul style="list-style-type: none"> <li>Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> </ul> | ---<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A | -----<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A | -----<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A |

|    |  |           |          |       |
|----|--|-----------|----------|-------|
|    | ➤ Auto Starting/ Manual stopping   | N/A       | N/A      | N/A   |
|    | ➤ Pump House Access  | N/A       | N/A      | N/A   |
|    | • Terrace level  | ----      | -----    | ----- |
|    | ➤ Discharge of pump  | 450 LPM   | 450 LPM  | MR    |
|    | ➤ Head of the pump   | 30 mtr.   | 30 mtr.  | MR    |
|    | ➤ Power Supply   | N/A       | N/A      | N/A   |
|    | ➤ Auto Starting of pump  | Required  | Provided | MR    |
| 14 | <b>Captive Water Storage for fire fighting</b>                           |           |          |       |
|    | • Underground tank capacity  | N/A       | N/A      | N/A   |
|    | ➤ Draw-off connection  | N/A       | N/A      | N/A   |
|    | ➤ Fire service inlet   | N/A       | N/A      | N/A   |
|    | ➤ Access to tank   | N/A       | N/A      | N/A   |
|    | • Overhead Tank capacity   | 10000 Lts | Provided | MR    |
| 15 | <b>Exit Signage.</b>   | Required  | Provided | MR    |
| 16 | <b>Provision of Lifts.</b>   |           |          |       |
|    | • Pressurization of Lift Shaft   | N/A       | N/A      | N/A   |
|    | • Pressurization of Lift lobby   | N/A       | N/A      | N/A   |
|    | • Communication In lift Car  | N/A       | N/A      | N/A   |
|    | • Fireman's Grounding Switch   | N/A       | N/A      | N/A   |
|    | • Lift Signage   | N/A       | N/A      | N/A   |
| 17 | <b>Standby power supply</b>  | N/A       | N/A      | N/A   |
| 18 | <b>Refuge Area.</b>  |           |          |       |
|    | ➤ Total Area   | N/A       | N/A      | N/A   |
|    | ➤ Location   | N/A       | N/A      | N/A   |
| 19 | <b>Fire Control Room</b>   |           |          |       |
|    | • Detector System Panel  | N/A       | N/A      | N/A   |
|    | • Flow Switch Panel  | N/A       | N/A      | N/A   |
|    | • PA System Panel  | N/A       | N/A      | N/A   |
|    | • Batter backup  | N/A       | N/A      | N/A   |
|    | • Building Floor Plans   | N/A       | N/A      | N/A   |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A       | N/A      | N/A   |

Main road width varies from 2.65 to 3.70 mts. but there is open space available from which fire engine can reach upto school building. It is the responsibility of owner to keep clear open space for fire engine to reach upto building. If this open space will not be available in future then FSC will stand null and void automatically.




N/21

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No F.6/DFS/MS/ School/2018/801 dated 24.04.2018, renewal under the Directorate of Education circular No. 262- 362 dated 17.01.2005 is recommended.

Accordingly, DFA is put up please, if agreed please

  
(P.V Rathee)  
Asstt. Divisional Officer (SRD.)


DY CFO (S2)

F.I. please -



A DO (S.R.D.)

E.T. letters put up for sign please.

DY CFO -  


M.S. 