

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No.F6/DFS/MS/FW/2021/ 194

Dated: 30/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s Sanjay Traders at Shop No.1, DDA Shopping Centre, Type S-1, GF, CSR No-3, Sector-1, Rohini, Delhi-110085 proposed for running the trade of Sale and Possession of 300 Kg Fire Works and 1200 Kg Chinese Sparkles at the ground floor owned/occupied by Sanjay Traders was issued Fire Safety Certificate by this department vide letter **No. F.6/DFS/MS/FW/2016/WZ/1586 dated 26.10.2016**. The premises was re-inspected by the officer concerned of this department on **03.03.2021** in presence of Sh. Sanjay Sharma and observed the premises is deemed complied with fire prevention and fire safety requirements in accordance with Guidelines issued by Additional Commissioner of Police (Lic) and fit for occupancy Class Fire Works with effect from 30/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under rule 38 of Delhi Fire Service Rules-2010.

Issued on 30/03/21 at New Delhi.

(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
Ph-011-23414250

Copy to:-

1. Sh. Sanjay Sharma, M/s Sanjay Traders at Shop No.1, DDA Shopping Centre, Type S-1, GF, CSR No-3, Sector-1, Rohini, Delhi-110085
2. The Additional Commissioner of Police, Licensing, Police Station, 1<sup>st</sup> floor, Defense Colony, New Delhi

**Conditions for the validity of fire safety certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

### INSPECTION REPORT


1. Name & address of the building : M/s Sanjay Traders at Shop No.1, DDA Shopping Centre, Type S-1, GF, CSR No-3, Sector-1, Rohini, Delhi-110085
2. Type of Occupancy : Class Fire Works ( Gr. Floor)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/2015/FW/WZ/1158 Dated 02.07.2015
5. Fire Safety directives letter No : N/A
6. Date of inspection : 03.03.2021
7. Name of Inspecting Officer : A.K. Sharma
8. Name and designation of officers  
From the building side : Sh. Sanjay Sharma
9. Year of Construction : N/A
10. Applicant's letter No. : PFW/7/2015/912-13/Joint CP/Lic.(Expl), Dated 29.10.2020

S. No.	Point of Inspection	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Type of construction and floor area &amp; floor level</b>			
	a. Minimum floor area	Accessible	Accessible	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase/Mean of escape	Provided	MR
	d. Business permissible only at ground floor level	Required	Provided	MR
	e. Business from pavement of road prohibited	Prohibited	Provided	MR
<b>2.</b>	<b>Entrance &amp; Exits to the Licensed Premises</b>			
	The Licensed premises shall have independent entrance and exit	Required	Provided	MR
<b>3.</b>	<b>Type and distance of the surrounding risk</b>			
	The premises shall be situated at a distance of 15m from any such premises used for similar explosive/inflammable or hazardous material	Required 15m	Provided	MR
<b>4.</b>	<b>Nature of business run in the licensed premises</b>			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purpose	Required	Provided	MR
<b>5.</b>	<b>Type of electrical wiring and electrical fitting</b>			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided with Casing & Capping	MR
<b>6.</b>	<b>Extension of shop for business</b>			
	Prohibited	Prohibited	Yes	MR
<b>7.</b>	<b>Approach Road</b>			
	The road width on the side of which premises is located should be 12m	12m	12m	MR
<b>8.</b>	<b>Fire Protection Arrangement</b>			
	a. Extinguisher Type and No's	7no. of Water type & ABC/CO <sub>2</sub> type	Provided	MR
	b. Sand and water buckets	3 No's Each	Provided	MR
	c. Water Drum	1 No.	Provided	MR
<b>9.</b>	<b>Any Other point that is contrary to the safety of people-NA-</b>			

The fire protection systems provided in the building premises were test checked and found functional at the time of inspection.



Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the DFS rules of NOC issued vide letter no. F6/DFS/MS/2015/FW/WZ/1158 Dated 02.07.2015, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

Accordingly DFA is put up for approval for signature please

  
10/3/21


Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)


DO(NW)


  
10/03/2021  
By ADO (NW)  
  
12/8/2021

ADO Rohini

FT letter is put up for kind perusal and signature please.

  
12/8/2021

  
12/8/2021

  
10/3/21

msg cell