

C/55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/EH/SZ/2021/ 81

Dated. 01./04./2021

FIRE SAFETY CERTIFICATE

Certified that My Square (A Unit of Versatile Food Courts Pvt. Ltd.), Select City Walk Mall, Saket, A-3, District Centre, New Delhi 110017 located at S-01, 2nd floor in the Building comprised of three tier basement, ground plus seven upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2018/SZ/944 dated 08/05/2018. The premise was re-inspected by the officer concerned of this department on 30/03/2021 in the presence of Mr. Mashooque Iqbal (Fire Safety Officer/ Mall) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" (Restaurants at 2nd floor only) as above with effect from 01./04./2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01 / 04 /2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi- 110016
2. The Joint C P (Lic.) P.S. Defence Colony, New Delhi -110049
3. M/s My Square (A Unit of Versatile Food Courts Pvt. Ltd.) at shop No S-01, 2nd Floor, Select City Walk Mall, Saket, A-3, District Centre, New Delhi 110017

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s My SQUARE at Shop No S-1, 2 nd Floor, Select City Walk Mall, A-3 Distt. Center, Saket, New Delhi. (A Unit of Versatile Food Courts Pvt. Ltd)		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant)		
3	Building Comprised of	03 tier Basements, Ground + 07 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2018/SZ/944 dated 08/05/2018		
6	Fire Safety Directives Letter No	F.6/MS/DFS/BP/2006/1141 dated 15/05/2006 & F.6/MS/DFS/BP/2016/299 dated 23/11/2016		
7	Date of Inspection	30/03/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Mashooque Iqbal (Fire Safety Officer/ Mall)		
10	Year of construction	2007	Restt located at 2 nd floor of Mall bldg	
11	Applicant letter No.	Through Gmail dated 17/03/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	(Select City Walk Mall - F.6/DFS/MS/Mall/2021/SZ/171 Dt. 15/03/2021)		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restt. within DLF Promenade Mall	Provided by Mall N/A N/A	MR N/A N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Provided & Maintained by Select City Walk, Saket		
	➤ Upper floors.	Restt within Mall	As above	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase	Provided & Maintained by Select City Walk, Saket		
	➤ Upper floors	Restt within Mall	As above	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits	Provided & Maintained by Select City Walk, Saket		
	➤ Fire check door	Restt within Mall	As above	MR
	➤ Pressurization	Restt within Mall	As above	MR
	d) No. of continuous staircase to terrace	Restt within Mall	-NA-	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	02 required	Open front & 4 exits towards open terrace	MR
3	Compartmentation.	Provided & Maintained by Select City Walk, Saket		
	• Fire check door.	Restt within Mall	As above	MR
	• Sealing of electrical shafts.	Restt within Mall	As above	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	Provided & Maintained by Select City Walk, Saket		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	Fire Extinguishers.			
	• Total numbers	Required	10 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI Marking	Required	Provided	MR
6	First Aid Hose Reels.	Provided & Maintained by Select City Walk, Saket		
	• Total numbers on each floor.	Two near Restt	As above	MR
	• Length of hose-reel hose.	30m	As above	MR
	• Nozzle Diameter	5mm	As above	MR
7	Automatic fire detection & alarming system.	(Provided & Maintained by Select City Walk, Saket)		
	• Type of detectors	Required	Smoke & heat	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	Required	As above	MR
	• Alternate source of power	Required	As above	MR
	• Hooter's location	Required	As above	MR

8	MOEFA	Required	As above	MR
9	Public Address System	N/A	As above	MR
10	Automatic Sprinkler System	Provided & Maintained by Select City Walk, Saket		
	• Basement	Required	As above	MR
	• Upper floor	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.	Provided & Maintained by Select City Walk, Saket		
	• Size of Riser/Down-comer	Required	As above	MR
	• Number of Hydrant per floor	One near Restt	As above	MR
	• Hose box.	One near Restt	As above	MR
12	Yard Hydrants.	Provided & Maintained by Select City Walk, Saket		
	• Total number of hydrants.	N/A	As above	N/A
	• Hose box.	N/A	As above	N/A
13	Pumping arrangements.	Provided & Maintained by Select City Walk, Saket		
	• Ground Level	Common pumping arrangements for entire bldg		
	➤ Discharge of main pump.	4500 LPM	As above	MR
	➤ Head of main pump.	88m	As above	MR
	➤ Number of main pumps.	02 Nos.	As above	MR
	➤ Jockey Pump output.	180 LPM	As above	MR
	➤ Jockey Pump head.	88m	As above	MR
	➤ Standby Pump output.	4500 LPM	As above	MR
	➤ Standby Pump head.	88m	As above	MR
	➤ Auto Starting/Manual Stopping.	Required	As above	MR
	➤ Pump house access.	Required	As above	MR
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	As above	MR
	➤ Head of pump.	40 m	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14	Captive water storage for fire fighting.	Provided & Maintained by Select City Walk, Saket		
	• Underground tank capacity.	Required	5,00,000 ltrs	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	Required	30,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Provided & Maintained by Select City Walk, Saket		
	• Pressurization of lift shaft.	N/A	As above	N/A
	• Pressurization of lift lobby.	N/A	As above	N/A
	• Communication in lift car.	N/A	As above	N/A
	• Fireman's switch.	N/A	As above	N/A
	• Lift signage.	N/A	As above	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.	Provided & Maintained by Select City Walk, Saket		
	• Detector system panel.	N/A	As above	N/A
	• Flow switch panel.	N/A	As above	N/A
	• PA system panel.	N/A	As above	N/A
	• Battery backup.	N/A	As above	N/A
	• Building floor plan.	N/A	As above	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	As above	N/A

2/119

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2018/SZ/944 dated 08/05/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

RK
30/3/2021

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

F.T. Place

DO (SD) on Leave
Dy. CFO (SZ)

[Signature]
30/3

ADO (BCP)

As approved, f.t. letter is put up for your signature pl

1/14
3/1/3

M.S. [Signature]