

C-85

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001
No.F6/DFS/MS/EH/NDZ/2021/ 82 Dated : 5/4/2021

FIRE SAFETY CERTIFICATE

Certified that the **DIMPLE Restaurant, 2105, D.B. Gupta Road, Karol Bagh, New Delhi** comprises of Basement, ground + 02 upper floors but restaurant running at Ground floor only was earlier granted FSC vide letter No. F6/DFS/MS/EH/2013/SZ/1001 dated 30/09/13. Now, the premises was re-inspected by officer concerned of this department on 18/03/2021 in the presence of Sh. Vijay Sethi and found that the said premises deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building Group D, **Restaurant at Ground floor only** with effect from ~~5/4/21~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~5/4/21~~ at New Delhi by.


1/4/21

(Dr. S.K Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Commissioner of Police(Lic) , Ist floor,PS Defence Colony , New Delhi Online Online ID no. 2020072305816 date 20/12/20
2. The Manager,
M/S DIMPLE Restaurant, 2105, D.B. Gupta Road, Karol Bagh, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J'[sub rule (I) of rule 37]along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is strictly prohibited.
10. This Fire Safety Certificate is valid for Ground Floor only.

INSPECTION REPORT

- | | |
|-------------------------------------|--|
| 1. Name & address of the building | DIMPLE Restaurant, 2105, D.B. Gupta Road, Karol Bagh, New Delhi comprised of basement ground two upper floor |
| 2. Type of occupancy:- | Assembly occupancy group -D and Restaurant is running at ground floor only |
| 3. Type of case:- | Renewal |
| 4. Details of previous FSC:- | F6/DFS/MS/EH/2013/SZ/1001 dated 30/09/13 |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 18/03/2021 |
| 7. Name of the inspecting officer:- | Sh. Ravinder Singh (ADO/CC) |
| 8. Name & designation of officer | From the building side:- Sh. Vijay Sethi |
| 9. Year of construction:- | Before 2005 |
| 10. Applicant's letter No:- | Online ID no. 2020072305816 date 20/12/20 |

The said restaurant is running on ground floor of a building comprised of basement, ground plus three upper floors.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mts	Provided	MR
	2) Gate width	4.5 mts	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	-	-	Rest. Running at GF only
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	-	-	Rest. Running at GF only
	2. Basements	Required	1.30 mts , 1.15 mts.	MR being old case
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2.0 mts	Provided (2.0 mts. & 0.95 mt.)	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan Provided	MR
	2) Upper floors	12 a/c per hour	Natural ventilation provided	MR
5.	Fire Extinguishers			

	1) Total numbers	07	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA			
9.	Public Address System			
		N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	---	---	---
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	35 mts	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

N/19

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	Required	Provided	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2013/SZ/1001 dated 30/09/13, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

[Handwritten Signature]
24/3/21

Name :- Ravinder Singh
Designation :- ADO (CC)

[Handwritten Signature]
DO (CC)

[Handwritten Signature]

23/3/21

Pl. speak

[Handwritten Signature]
24/3/21

1. spoken on 31/3/21.
2. Resubmitted pl.



[Handwritten Signature]
DO (CC)

[Handwritten Signature]
DO (CC)

[Handwritten Signature]