

42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Audi/2021/SZ/ 302

Dated: 5/4/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Dr. S. R. KVS Auditorium Building at Kendriya Vidyalaya No.-2, Delhi Cantt, New Delhi-110010, comprised of Ground Floor & Two Upper Floors only, owned / occupied by Kendriya Vidyalaya Sanghathan, has already been issued Fire Safety Certificate vide Letter No. F6/DFS/MS/2017/SZ/713 dated 18/05/2017. The premises / Building was re-inspected by the officer concerned of Fire Service on 31.03.2021 in the presence of Sh. Tushar Mittal (Care Taker) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Group - D) (Auditorium) with effect from 5/4/2021 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 5/4/2021 at New Delhi.

(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. Authorized Signatory, Kendriya Vidyalaya No.-2, Delhi Cantt, New Delhi-110010.
2. Addl. Commissioner of Police (Lic.), PS Defence Colony, New Delhi-110049.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. All the employees equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures management shall be responsible.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

1. Name & address of the building: **Dr. S. R. KVS Auditorium Building at Kendriya Vidyalaya No.-2, Delhi Cantt, New Delhi-110010.**
2. Type of Occupancy : **Ground "D" Assembly Building,**
3. Building Comprised of : **Ground & Two Upper Floors. (Auditorium at Ground & 1<sup>st</sup> Floor and having balcony at 2<sup>nd</sup> Floor, Ground Floor & 1<sup>st</sup> Floor Common Hall=573 seats & Balcony=184 seats Total seats=757.**
4. Type of Case : **Renewal**
5. Details of previous NOC : **F6/DFS/MS/2017/SZ/713 dated 18/05/2017**
6. Fire Safety directives Letter No. : **F6/DFS/MS/BP/2012/3496 dated 24/09/2012**
7. Date of inspection : **31/03/2021**
8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
9. Name and designation of Officer from the building side : **Sh. Tushar Mittal (Care Taker)**
10. Year of Construction : **2006**

11. Applicant's letter received through email [ID-kv2delhicantt@yahoo.com](mailto:ID-kv2delhicantt@yahoo.com) dated 09/03/2021


S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	14 m	MR
	• Gate width	5 m	5 m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3 & 2 Ramps	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m (Each)	1.50m (Each) and 2 Ramps 1.45m & 1.40m	MR (old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	10 Exit Gates of 1.50 mtr	06 Exit Gates at Ground Floor- 1.80m (Each) & 04 Exit Gates at Balcony of 1.80m (Each)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	24 Nos	35 Nos	M/R
	• Types	ABC/w.co2/CO <sub>2</sub>	Provided	M/R


	Total numbers on each floor	Required	At Ground Floor=8, 1 <sup>st</sup> Floor & 2 <sup>nd</sup> Floor=1 (Each)	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Beam	Smoke & Beam	MR
	• Location of Main Panel	Ground floor	Ground floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Battery backup	MR
	• Hooters' Location	All Areas	All Areas	MR
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	Required	At Ground Floor=8, 1 <sup>st</sup> Floor & 2 <sup>nd</sup> Floor=1 (Each)	MR
	• Hose Box	Required	At Ground Floor=8, 1 <sup>st</sup> Floor & 2 <sup>nd</sup> Floor=1 (Each)	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	1620 LPM	1620 LPM	MR
	➤ Head of main pump	60 m	60 m	MR
	➤ Number of main pumps	01 No	01 No	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	60 m	60 m	MR
	➤ Standby Pump out put	1620 LPM	1620 LPM	MR
	➤ Standby Pump Head	60 m	60 m	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 Ltr	50,000 Ltr	MR
	➤ Draw of connection	Required	Provided	MR

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	ABC & CO2 Fire Extinguishers	Provided for Electrical Panel	MR


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2017/SZ/713 dated 18/05/2017** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Done on leave  
 Dy CPO (SZ) F.T.  


  
 30/03

Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation : A.D.O. (S.J.)

A.D.O. (S.J.)  


FT letter is put-up for signature please