

4/70

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/ 300

Dated:- 5/04/2021

FIRE SAFETY CERTIFICATE

Certified that the **East Point School** located at **FC-26, Dallupura, Vasundhara Enclave, Delhi – 110096** comprised of **B+ Gr. + 03 upper floors** was granted FSC by this department vide letter No. **F6/DFS/MS/School/2017/NDZ/1849** dated **20/12/2017**. The premises was re-inspected by the officers concerned of this department on 20/03/2021 in the presence of the Mrs. Archana Shrivastava (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **“B” ‘Educational Building’** with effect from **5/4/21** for a period of **three** years, subject to conditions, printed below.

Issued on **5/4/21** at New Delhi by


114121

(Dr. S.K Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Joint Director of Education,
(Land & Estate),
Directorate of Education, Lucknow Road, Delhi -54.
2. The Principal,
East Point School,
FC-26, Dallupura, Vasundhara Enclave, Delhi – 110096.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

N/24

INSPECTION REPORT

1. Name & address of the building:- East Point School, FC-26, Dallupura, Vasundhara Enclave, Delhi – 110096.
2. Type of occupancy:- Educational Building
B+Gr.+03 upper floors (building divide in 4 blocks)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/2017/NDZ/1849 dated 20/12/2017
5. Fire safety directives No.- F6/DFS/MS/BP/2017/189 dated 21/06/2017
6. Date of inspection:- 18/12/2020
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mrs. Archana Shrivastava (Principal)
9. Year of construction:- Old Building
10. Applicant's letter No:- email dated 15/02/2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr.	MR
	2) Gate width	4.5 mtr.	5.0 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	07	07	MR
	2. Basements	07	07	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr(each block)	04 Nos. of 1.5 mtr., 02 nos. of 1.8 mtr. & 01 no. of 2.0 mtr.	MR
	2. Basements	1.5 mtr(each block)	04 Nos. of 1.5 mtr., 02 nos. of 1.8 mtr. & 01 no. of 2.0 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	2 hrs.	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	24 Nos.	30 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR

N/25

6.	First-Aid Hose Reel			
	1) Total number of each floor	01(Each block)	Provided	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01(each block)	Provided	MR
	3) Hose box	01(each block)	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	Provided	MR
	b) Head of pump	40 m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltr.(in each block)	Provided	MR

M

N/26

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2020/NDZ/04 dated 15/01/2021 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2017/NDZ/1849 dated 20/12/2017, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma
243124

Name :- M.K. Sharma
Designation :- ADO (LN)

[Signature]
DO/ED
2413

[Signature]
DY. CFS/MW-3 R.A. PL

[Signature]
2513121

[Signature]
ADOC (LN)



[Handwritten notes at the bottom of the page]