GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F6/DFS/MS/Hotel/2021/ / 4

Dated:-.9./04/2021

FIRE SAFETY CERTIFICATE

Certified that **The Hotel Imperial** located at **No. 1, Janpath, New Delhi** comprised of **2Basement** + **Ground** + **03 Upper floors** was granted FSC by this department vide letter **No.** F6/DFS/MS/2017/Hotel/NDZ/545 dated 13/04/17. The premises was re-inspected by the officer concerned of this department on **01/04/21** in the presence of Sh. Arun Kumar & Sh. Suresh Bedi (Fire Safety Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Sub division A-6 Starred Hotel of Group 'A' Residential Building** with effect from **-9-1-4-1-2-1** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

DIRECTOR
Delhi Fire Service

Copy to:-

- 1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ref. online ID no. 2020110208212 dated 02.11.20.
- 2. The Manager, The Hotel Imperial located at No. 1, Janpath, New Delhi.

Condition for the validity of fire safety certificate

- 1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.

3. The trained fire fighting staff should be available round the clock.

- 4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9. Any flammable material for interior decorations such as carpet, wooden materials, etc shall strictly be prohibited.

Renewal 3. Type of case:-No. F6/DFS/MS/2017/Hotel/NDZ/545 4. Details of previous FSC:dated 13/04/17. F6/DFS/MS/BP/2007/2206 dated 5. Fire safety directives No.-13.08.2007 01/04/21 6. Date of inspection:-Sh. Rajinder Atwal (DO/CD) & 7. Name of the inspecting officer:-Sh. Ravinder Singh (ADO/CC) 8. Name & designation of officer Sh. Arun Kumar & Mr. Suresh Bedi (fire from the building side:officer) 1947 9. Year of construction:e-mail kchand@theimperialindia.com & online ID. 10. Applicant's letter No:-2020110208212 dated 02.11.20 Old Case Existing fire Provided at site Remarks Minimum Standards on fire S.No. MR/NMR Prevention and fire safety safety arrangements U/R 33 /Requirement as per NBC Access to Building 1. MR 30 mtr. 12 mtr. 1) Road width MR 05 mtr. 05 mtr. 2) Gate width MR 06 mtr. 06 mtr. 3) Width of internal road Number, Width Type & Arrangement of Exits 2. A. Number of staircases MR 04 Nos. Hotel 04 Nos. 1. Upper floors MR 03Nos. 2. Basements 03Nos. B1 (Laundry& services) MR 02 nos 02nos B2 (Pump room & services) B. Width of staircase MR(old 02 of 2.0m for 1 m &1.5 m 1. Upper Hotel banquet up to case building floors first floor, 03 of renewal) 1.45 m. &01 of 1.20 m. Up to terrace MR(old 1.0,1.5 & 1.8 m B-1 basement 1 mtr. 2. Basements case (Laundry& renewal) services) 1.5 & 1.2 m MR(old B-2 (Pump 1mtr case room & renewal) services) C. Protection of exits MR Provided Required 1. Fire check door NA NA NA 2. Pressurization MR 03 02 D. No. of continuous staircase to terrace MR 2.4 mtr. 1.5 mtr. E. Width of corridor MR 01 mtr. 01 mtr. F. Door size Compartmentation 3. MR Provided Required 1) Fire check door MR Provided 2) Sealing of electrical shafts Required

2. Type of occupancy:-

02B+G+3upper

Residential building (A-6 stared hotel)

| | 2) Upper Hoors | 12 a/c per | Provided | MR | | |
|----------|--|---|--|---|--|--|
| 5. | Eine Entinenish aus | hour | * | | | |
| 5. | Fire Extinguishers 1) Total numbers | 220 Nos. | 280 Nos. | MR | | |
| | 2) Types | ABC & CO2 | ABC & CO2 | MR | | |
| | 3) ISI marking | Required | Provided Provided | MR | | |
| 6. | First-Aid Hose Reel | | | | | |
| | 1) Total number of each | 06 | Provided | MR | | |
| | floor | | | | | |
| | 2) Length of hose reel hose | 30 mtr. | 30 mtr. | MR | | |
| | 3) Nozzle diameter | 06 mm | 06 mm | MR | | |
| 7. | Automatic Fire Detection & | em | | | | |
| - | 1) Type of | Smoke, Heat, | Provided | MR | | |
| | detectors, Heat/Smoke | Beam | | | | |
| | | Required | - | 1 | | |
| | 2) Location of main panel | Gr. Floor | Provided | MR | | |
| | 3) Location of repeater panel | Floor wise | Provided | MR | | |
| | 4) Alternate source of power5) Hooter's Location | Required Floor wise | Provided Provided | MR MR | | |
| 0 | | | Provided | | | |
| 8. 9. | MOEFA Public Address System | Required Required | Provided | MR MR | | |
| 10. | Public Address System Automatic Sprinkler System | Required | riovided | IVIK | | |
| 10. | 1) Basement | Required | Provided | MR | | |
| | 2) Upper floors | Required | Provided | MR | | |
| | 3) Sprinkler above false | Required | Provided | MR | | |
| | ceiling | 1 | Charles and the Charles and th | | | |
| 11. | Internal Hydrants | | | | | |
| | 1) Size of riser/down-comer | 6" dia | Provided | MR | | |
| | 2) Number of hydrants per | 05 | Provided | MR | | |
| | floor | | | | | |
| | 3) Hose box | Near hydrant | Provided | MR | | |
| 10 | X IXI | point | | | | |
| 12. | Yard Hydrants | 04 | 04 | MR | | |
| | 1) Total number of hydrants 2) Hose box | 17 | 17 | MR | | |
| 13. | Pumping Arrangement | 17 | 17 | IVIIC | | |
| 13. | 1) Ground level | | | | | |
| | a) Discharge of main | 2850 LPM | 2850 LPM | MR | | |
| | pump | | | | | |
| | | | | | | |
| | | 70 mtr. | 70 mtr. | MR | | |
| | * * | 02 | 02 | MR | | |
| | b) Head of main pumpc) Number of main pumpd) Jockey pump out put | 02 180 LPM | 02 180 LPM | MR MR | | |
| | b) Head of main pumpc) Number of main pumpd) Jockey pump out pute) Jockey pump head | 02 180 LPM 70 mtr. | 02 180 LPM 70 mtr. | MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output | 02 180 LPM 70 mtr. 2280 LPM | 02 180 LPM 70 mtr. 2280 LPM | MR MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. | MR MR MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual | 02 180 LPM 70 mtr. 2280 LPM | 02 180 LPM 70 mtr. 2280 LPM | MR MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. | MR MR MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided | MR MR MR MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided | MR MR MR MR MR MR | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. | MR MR MR MR MR MR MR N/A N/A | | |
| | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided | MR MR MR MR MR MR | | |
| 14. | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply d) Auto starting of pump | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A | 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. Provided | MR MR MR MR MR MR MR N/A N/A N/A | | |
| 14. | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A | 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. Provided | MR MR MR MR MR MR MR N/A N/A N/A | | |
| 14. | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply d) Auto starting of pump Captive Water Storage for Fi 1) Under ground tank capacity | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A N/A N/A ire Fighting | 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. Provided Provided 1,50,000 litr. | MR MR MR MR MR MR MR N/A N/A N/A N/A N/A | | |
| 14. | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply d) Auto starting of pump Captive Water Storage for Fi 1) Under ground tank capacity a) Draw-off connection | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A N/A N/A ire Fighting 1,50,000 litr. Required | 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. Provided 1,50,000 litr. Provided | MR MR MR MR MR MR MR MR N/A N/A N/A N/A N/A N/A N/A | | |
| 14. | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply d) Auto starting of pump Captive Water Storage for Fi 1) Under ground tank capacity a) Draw-off connection b) Fire service inlet | 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A N/A N/A N/A Repuired Required Required | 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. Provided Provided 1,50,000 litr. Provided Provided | MR MR MR MR MR MR MR MR N/A N/A N/A N/A N/A N/A N/A N/A | | |
| 14. | b) Head of main pump c) Number of main pump d) Jockey pump out put e) Jockey pump head f) Stand by pump output g) Stand by pump head h) Auto starting/Manual stopping 2) Terrace level a) Discharge of pump b) Head of pump c) Power supply d) Auto starting of pump Captive Water Storage for Fi 1) Under ground tank capacity a) Draw-off connection | 02 180 LPM 70 mtr. 2280 LPM 70 mtr. Required N/A N/A N/A N/A N/A ire Fighting 1,50,000 litr. Required | 180 LPM 70 mtr. 2280 LPM 70 mtr. Provided 450 LPM 70 Mtr. Provided 1,50,000 litr. Provided | MR MR MR MR MR MR MR MR N/A N/A N/A N/A N/A N/A N/A | | |



| | a) Pressurization of lift shaft | Required | Provided | MR |
|-----|---|----------|------------|-----|
| | b) Pressurization of lift lobby | Required | Provided | MR |
| | c) Communication in lift car | Required | Provided | MR |
| | d) Fireman's switch | Required | Provided | MR |
| | e) Lift signage | Required | Provided | MR |
| 17. | Stand by Power Supply | Required | Provided | MR |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | a) Detector system panel | Required | Provided - | MR |
| | b) Flow switch panel | Required | Provided | MR |
| | c) PA system panel | Required | Provided | MR |
| | d) Battery backup | Required | Provided | MR |
| | e) Building floor plan | Required | Provided | MR |
| 20. | Special Fire Protection Syste Risk, if any: total Co ₂ flooding | MR | | |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. . F6/DFS/MS/2017/Hotel/NDZ/545 dated 13/04/17, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the inspecting officer

Signature of the Inspecting Officer

Name: - Rajinder Atwal Designation: - DO (CD) Name: Ravinder Singh Designation: ADO (CC)