

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2021/NDZ/ 84

Dated: 5/4/21

FIRE SAFETY CERTIFICATE

Certified that the M/s Barshala (A Unit of Indospirit Bars Pvt. Ltd.) running at first floor of building comprised of ground and one upper floor located at Unit 108, First Floor, Station Box Area (PD Area), Dilshad Garden Metro Station, Delhi – 110095 owned/occupied by Indospirit Bars Pvt. Ltd. The premises was inspected by the officer concerned of this department in the presence of Sh. Sumit Wadhera and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that Eating House is fit for occupancy Group D "Assembly Building" for first floor with effect from 5/4/21 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 5/4/21 at New Delhi by


(Atul Garg)
Director

Delhi Fire Service+

To,

Sh. Sumit Wadhera
H. No. 207, Jor Bagh,
Lodhi Raod, Delhi-110003

OIC BSR

Copy To:-

The Addl. Commissioner of Police (Lic.)
First floor, Police station Defence Colony
New Delhi



MHA ID No. 2020101307641

Conditions for the validity of Fire Safety Certificate

1. This NOC is valid for first floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

- M18
1. Name & address of the building : M/s Barshala (A Unit of Indospirit Bars Pvt. Ltd.)
Unit 108, First Floor, Station Box Area (PD Area)
Dilshad Garden Metro Station, Delhi – 110095.
 2. Building is comprised of : Ground, Mezzanine & Concourse (PD Area)
(Restaurant running on first floor in PD Area)
 3. Type of Occupancy : Assembly (Restaurant)
 4. Type of Case : New
 5. Details of Previous NOC letter : Nil
 6. Fire Safety directive letter No : NBC Part IV
 7. Date of Inspection : 20/03/2021
 8. Name of the Inspecting officers : DO F. Brown
 9. Name and designation of Officer
from the building side : Mr. Sumit Wadhera (Owner)
 10. Year of Construction : 2007-2008.
 11. Applicant's letter No : 2020101307641 dated 18/03/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr. N/A N/A	18 mtr. N/A 06 mtr.	MR N/A MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	02 nos. N/A	03 nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	02 mtr N/A	3.47 mtr x 2 & 1.35 mtr N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	Provided N/A	MR N/A
	d. No. of Continuous Staircases to Terrace	01 no.	02 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
	g. No. of Door	02 nos.	02 nos	MR
03	Compartmentation.	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A Required	N/A Natural ventilated	N/A MR
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 nos. ABC /CO ₂ ISI marked	06 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants	common with the Mall		
	• size of riser/down-comer	100 mm	150 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	14 nos.	MR
	• Hose box	N/A	14 nos.	MR
13	Pumping Arrangements.	Common with Metro Station		
	➤ Ground Level			
	• Discharge of main pump	2850 LPM	2850 LPM x2 & 1800 lpm	MR
	• Head of main pump	70 M	70 M	MR
	• Number of main pumps	01 nos	03 nos	MR
	• Jockey pump out put	225 LPM	225 LPM	MR
	• Jockey pump head	70 M	70 M	MR
	• Standby pump out put	2850 LPM	2850 LPM	MR
	• Standby pump head	70 M	70 M	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting	Common with Metro Station		
	• Underground tank capacity	2,00,000 ltr	2,00,000	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

Note:- This is ⁱⁿ a Metro Station building (2007-2008) and fire protection arrangements has been provided as per provision of NBC (Part IV) 2005 clause 6.4.8 and accordingly wet riser has been provided in lieu of down comer. NOC for whole P.D. Area has already been issued vide letter No. F6/DFS/MS/2017/NDZ/1115 dated 27/07/2017.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the ~~deemed~~ substantial compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, it is recommended to issue Fire Safety Certificate.

Signature of the Inspecting Officer
 Name :- F. Brown
 Designation :- D.O (ED)

Dy. CFO (NDZ)

[Handwritten Signature]
24/3/21

CFO (NDZ) - D/O B

Director / *[Handwritten Signature]*
30/03/2021

F.T. PLS

Sir, As approved F.T. letter is put up for signature please.

[Handwritten Signature]

[Handwritten Signature]
01/4/2021

