

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/INDL/2021/NDZ/ 204

Dated: 05/04/2021

FIRE SAFETY CERTIFICATE

Certified that the Industrial building at Plot No. 15, FIE, Patparganj Ind. Area, Delhi-110092, comprised of Basement, stilt ground plus two upper floors. The premises was inspected by the officer of this department in the presence of Mr. Sunit Shah on 24/03/2021 and found that the Industrial building have complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 33 of the Delhi Fire Service Rules, 2010 and observed that the industrial building fit for occupancy Group G-2 'Industrial Building' with effect from 05/04/2021... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 05/04/2021..... at New Delhi by


(Atul Garg)
Director

To,

Sh. Sunit Shah
Plot No. 15, FIE, Patparganj Ind. Area,
Delhi-110092.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Plot No. 15, FIE, Patparganj Ind. Area, Delhi-92
2. Building is comprised of : Basement, stilt, ground & two upper floor only
3. Type of Occupancy : Industrial Building
4. Type of Case : New
5. Details of Previous NOC letter : N/A
6. Fire Safety directive letter No : F6/DFS/MS/BP/2020/196 dated 08/06/20
7. Date of Inspection : 24.03.2021
8. Name of the Inspecting officers : D.O. Francis Brown
9. Name and designation of Officer
from the building side : Mr. Sunit Shah
10. Year of Construction : 2017 -2018
11. Applicant's letter No : E-Mail dt. 23/03/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	12 mtr.	13 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 No.	02 No.	MR
	• Basement	02 No.	02 No.	MR
	b. Width of Staircases			
	• Upper floor	1.5 mtr	1.5 mtr. each	MR
	• Basement	1.5 mtr	1.5 mtr. each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 No.	02 No.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Natural	MR
05.	Fire Extinguishers.			
	• Total numbers	10 nos.	12 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
		30 mtr.	30 mtr.	MR
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	N/A	100 mm	MR
		N/A	01 no.	MR
		N/A	01 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump Head of Main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting/manual stopping Pump house access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	900 lpm	900 lpm x 2	MR
		40 mtr	40 mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		20000 Ltr.	20000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Firemen's grounding switch Lift signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, it is recommended to renew Fire Safety Certificate.

Five safety arrangements ^{have} been provided.
as per Guide line issued vide letter No.

F.G/DFs/MS/BP/2020/196 dt 8/6/20

Dy.CFO (NDZ)

Signature of the Inspecting Officer

Name :- F. Brown

Designation :- DO (ED)

Q. J. Kumar
30/3/21

CFO (H.O.) Not available in the office.

Director | DFs. FTPL
31/03/21

Q. J. Kumar

F.G. letter is put up for signature pl.

Q. J. Kumar
31/3/21

Director

