

E-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 81

Dated: 7 / 4 /2021

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of **M/s Punjabi By Nature (A Unit of Anon Food and Beverages Pvt. Ltd)** located at **T- 305, 3rd Floor Ambience Mall, Vasant Kunj, New Delhi 110067**) comprised of three basement, ground plus three upper floor owned / occupied by M/s Punjabi By Nature (A Unit of Anon Food and Beverages Pvt. Ltd) was issued fire safety certificate by this department vide letter no F.6/DFS/MS/EH/2020/SZ/46 Dated 20/02/2020 for M/s Punjabi By Nature (A unit of A. R Fisheries Pvt. Ltd, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 23/03/2021 in the presence of Mr. Abu Saad (Manager) of the restaurant and that the premises is fit for occupancy class **“Group-D Assembly” (Restaurant running at 3rd floor of the building)** with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7 / 4 /2021 at New Delhi by


(Atul Garg)
Director
Ph. 011-23414000

Copy to: -

1. The Dy. Health Officer, South Zone, SDMC, Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016
2. Ms. Arti Girdhar, M/s Punjabi By Nature (A Unit of Anon Food and Beverages Pvt. Ltd) located at T- 305, 3rd Floor Ambience Mall, Vasant Kunj, New Delhi 110067.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Punjabi By Nature (A unit of Anon Food and Beverages Pvt. Ltd), T-305, 3 rd Floor, Ambience Mall, Vasant Kunj, New Delhi-110067		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	03 tier basement, ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2020/SZ/46 Dated 20/02/2020 for (A unit of A. R Fisheries Pvt. Ltd) M/s Punjabi By Nature		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23/03/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Abu Saad (Manager)		
10	Year of construction	2010	Restt running at 3 rd Floor of the building	
11	Applicant letter No.	Online Application no. 2021021810537 dated 06/03/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / UBBL Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building. FSC No.F.6/DFS/MS/Mall/2020/SZ/56 Dated 21/01/2020 of ambience mall			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtr	09 mtr	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	Two	Two near restaurant	MR
		N/A	N/A	N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	Required	Provided by Mall	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required	Provided by Ambience Mall	MR
		Required	Provided by Ambience Mall	MR
	d. No. of continuous staircase to terrace	Required	Provided by Ambience Mall	MR
	e. Width of corridor	Required	Provided by Ambience Mall	MR
	f. Door size	2 Nos	2 mtr & 1.10 (final exit)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	Required	Provided by Ambience Mall	MR
		Required	Provided by Ambience Mall	MR
		Required	Provided by Ambience Mall	MR
		Required	Provided by Ambience Mall	MR
		Required	Provided by Ambience Mall	MR
4.	Smoke Management system.			
	Provided & Maintained by Ambience Mall			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 a/c per hour	Provided By Mall	MR
		12 a/c per hour	Provided By Mall	MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	ISI marked	10 Nos.	MR
			ABC-06/ W.Co2-04	MR
			Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	Required	Provided by Ambience Mall	MR
		30 mtr	Provided by Ambience Mall	MR
		05 mtr	Provided by Ambience Mall	MR

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	Required	Smoke, Provided by Mall	MR
	• Location of Main Panel	Required	Provided by Mall	MR
	• Location of Repeater Panel	Required	Provided by Mall	MR
	• Alternate source of power	Required	Provided by Mall	MR
	• Hooter's location	Required	Provided by Mall	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	Provided & Maintained by Ambience Mall		
	• Basement	Required	Provided by Ambience Mall	MR
	• Upper floors	Required	Provided by Ambience Mall	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by Ambience Mall		
	• Size of Riser/Down-comer	Required	Provided by Ambience Mall	MR
	• Number of Hydrant per floor	Required	Provided by Ambience Mall	MR
	• Hose box.	Required	Provided by Ambience Mall	MR
12.	Yard Hydrants.	Provided & Maintained by Ambience Mall		
	• Total number of hydrants.	N/A	N/A	N/A
	• 2. Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.	Provided & Maintained by Ambience Mall		
	• Ground Level	Provided & Maintained by Ambience Mall		
	➤ Discharge of main pump.	Required	Provided by Ambience Mall	MR
	➤ Head of main pump.	Required	Provided by Ambience Mall	MR
	➤ Number of main pumps.	Required	Provided by Ambience Mall	MR
	➤ Jockey Pump output.	Required	Provided by Ambience Mall	MR
	➤ Jockey Pump head.	Required	Provided by Ambience Mall	MR
	➤ Standby Pump output.	Required	Provided by Ambience Mall	MR
	➤ Standby Pump head.	Required	Provided by Ambience Mall	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided by Ambience Mall	MR
	➤ Access to pump house	Required	Provided by Ambience Mall	MR
	• Terrace Level	Provided & Maintained by Ambience Mall		
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.	Provided & Maintained by Ambience Mall		
	• Underground tank capacity.	Required	Provided by Ambience Mall	MR
	➤ Draw-off connection.	Required	Provided by Ambience Mall	MR
	➤ Fire Service Inlet.	Required	Provided by Ambience Mall	MR
	➤ Access to tank.	Required	Provided by Ambience Mall	MR
	• Overhead tank capacity.	Required	Provided by Ambience Mall	MR
15.	Exit Signage.	Required	Provided by Ambience Mall	MR
16.	Provision of Lifts.	Provided & Maintained by Ambience Mall		
	• Pressurization of lift shaft.	Required	Provided by Ambience Mall	MR
	• Pressurization of lift lobby.	Required	Provided by Ambience Mall	MR
	• Communication in lift car.	Required	Provided by Ambience Mall	MR
	• Fireman's switch.	Required	Provided by Ambience Mall	MR
	• Lift signage.	Required	Provided by Ambience Mall	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room.	Provided & Maintained by Ambience Mall		
	• Detector System Panel.	Required	Provided by Mall	MR
	• Flow Switch Panel.	Required	Provided by Mall	MR
	• PA system Panel.	Required	Provided by Mall	MR
	• Battery backup	Required	Provided by Mall	MR
	• Building floor plan	Required	Provided by Mall	MR
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	Provided by Mall	MR

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

Handwritten signature and date: 25/03/2021

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

DO (SD)

Handwritten signature and date: 28/03/21

Handwritten signature and date: DeFO (2) 30/3

Handwritten signature and date: C.F.O. 30/3

Handwritten signature and date: 30/3

Handwritten signature and date: 30/03/2021

Handwritten signature

Handwritten signature

Please explain 'A'

Handwritten note: 'A' | Govt + Govt ... See DFA

Handwritten signature and date: 31/3

