

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/WZ/2021/ 99

Dated: 13/4/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Smelling Salts Restaurant** situated at **Upper Ground Floor, Plot no. 13, Block C2, Ashok Vihar, Phase-2, New Delhi-110052**, in a building comprised of B+Stilt+UGF+02 Upper Floor owned/ occupied by M/s. **Smelling Salts Restaurant** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on **01.04.2021** in the presence of **Sh. Sanjay Batra (Owner) & Sh. Rahul Sharma (Manager)** and that the said building is fit for occupancy class "Assembly" Group D (**Restaurant**) with effect from 13/4/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on13/4/21.... at New Delhi by.


(Atul Garg)

Director
Delhi Fire Service

This NOC is valid for only Upper Ground Floor

Copy to:-

1. The Addl. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
2. The Dy. Health Officer, Keshav Puram Zone, **NDMC**, Public Health Department, **A-1 Block** Keshav Puram Zone, Delhi.
3. Sh. Prashit Jain, M/s. Smelling Salts Restaurant Located at Plot no. 13, Block C2, Upper Ground Floor, Ashok Vihar, Phase-2, New Delhi-110052.


13/4/2021

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1. Name & address of the building: **M/s. Smelling Salts Restaurant Located at Plot no. 13, Block C2, Upper Ground Floor, Ashok Vihar, Phase-2, New Delhi-110052.**
2. Type of Occupancy : Class-D Assembly at **Upper Ground Floor** (in a building Comprised of B+Stilt+UGF+02^UUpper Floor)
3. Type of Case : New
4. Details of previous NOC Letter No. : Nil
5. Fire Safety directives Letter No. : As per BBL/NBC
6. Date of inspection : 01.04.2021
7. Name of the Inspecting Officer : M.K. Chattopadhyay, DO (West) & S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
From the building side: Sh. Sanjay Batra (Owner) & Sh. Rahul Sharma (Manager)
9. Year of Construction : 2016
10. Applicant's online application no. 2021010609444 dated 08.03.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width 	06 m	Provided	MR
	<ul style="list-style-type: none"> • Gate width 	4.5 m	Direct Accessible from road	MR
	<ul style="list-style-type: none"> • Width of internal road 	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors 	02	Provided	MR
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors 	1.5 m	Provided	MR
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	NA	One	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.5 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided in Restaurant	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	4 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC Type	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 Lpm	Provided	MR
	➤ Head of the pump	40mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC Type of Fire Extinguisher Provided near Electrical Panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirement under the rules, grant of Fire Safety Certificate is recommended under rules 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

[Signature]
05/04/2021

M. K. Chattopadhyay, DO (West)

[Signature]
05/04/21

S. P. Bhardwaj, ADO (WP)

D.O. (WEST) 113
DATED... 5/4/2021

[Signature]
DCFO (WZ)

[Signature]
9/4/2021



[Signature]
CFO

[Signature]
12/4

[Signature]
12/04/2021

[Signature]
ADW / WD

FT. letter is put up for signature P.
[Signature]
12/4/2021