

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/2021/CNG / 227

Dated: 13/07/2021

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) located at Sanjay Gandhi Transport, Phase-II, Delhi-110042, comprised of Single Story Building owned / occupied by Indraprastha Gas Limited was granted NOC by this department vide letter no F.6/DFS/MS/2018/CNG/784 dated 20.04.2018. The premises was re-inspected by officer concerned of this department on 30.03.2021 in the presence of Mr. Shivam Gupta (Dy. Manrager) and found that the premises have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises is fit for occupancy CNG Filling Station Group 'J' with effect from 13/07/2021 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Issued on 13/07/2021 at New Delhi by


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Ph:- 01123414250

Copy to:

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Center, R.K. Puram, Sect-9, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defense Colony, Delhi

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT**Gr. floor Only**

- 1.Name & address of the building : CNG Filling Station (IGL) at Sanjay Gandhi Transport Nagar-II, Phase-II, Delhi-110042.
2. Type of Occupancy : CNG Filling Station **Group "J"/ Business**
- 3.Type of Case : **Renewal (Gr. Floor only)**
- 4.Details of Previous NOC : F.6/DFS/MS/2018/CNG/784 dated 20.04.2018
- 5.Fire Safety directives letter No : Nil
- 6.Date of inspection : 30.03.2021
- 7.Name of Inspecting Officer : A.K. Sharma (ADO Rohini)
- 8.Name and designation of officers
From the building side : Mr. Shivam Gupta (Dy. Manager)
- 9.Year of Construction :
- 10Applicant's letter No. : Online e-mail Dated 08.03.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building[
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required NA NA	30 mtr NA NA	M/R NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	NA NA	NA NA
	d. No. of continuous staircases to terrace	N/A	NA	NA
	e. Width of Corridor	N/A	NA	NA
	f. Door Size	1.0 mtr	1.0 mtr	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A N/A	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	15 ABC/Co2 ISI marked	26nos. 06 trolley-75 kg 14 DCP & 06 Co2 Yes	MR MR MR
6.	First-Aid Hose Reels			

	<ul style="list-style-type: none"> Total numbers on each floor 	N/A	N/A	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	N/A	N/A	NA
	<ul style="list-style-type: none"> Nozzle diameter 	N/A	N/A	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for firefighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	NA	NA	NA

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Buckets filled with sand, No smoking board were found displayed in Hindi & English. No lose electric wiring were seen in premises & CO2 flooding system found provided		MR
21.	DCP spray system for cascade	Provided		MR

The fire protection systems provided in the building premises were test checked and found functional at the time of inspection.

in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the DFS rules of NOC issued vide letter no. F.6/DFS/MS/2018/CNG/784 dated 20.04.2018, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

Ajay
6/4/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO(NW) - on leave

~~DCPO(W2)~~

[Signature]
9/4/2021

~~ADO Rohini~~

FT letter is put up for kind perusal and signature please.

~~DCPO(W2)~~

MS/alf

[Signature]
9/4/2021

[Signature]
9/4/21