

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2021/CNG/ 212

Dated: 08/04/2021

FIRE SAFETY CERTIFICATE

Certified that the Indraprastha Gas Ltd. Retail Outlet (CNG Pump) at CGO Complex, Lodhi Road, New Delhi, comprised of Ground plus one upper floor only having 03 Cascades (at roof of the office bldg), 03 Compressor units & 17 Dispensing units, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/CNG/2018/SZ/861 Dated 27.04.2018. The premises was re-inspected by the officer concerned of this department on 19/03/2021 in the presence of Sh. Ajay Khatri (DGM Fire & Safety) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Hazardous" (CNG Pump) as above with effect from the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 08/04/2021 at New Delhi by.


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Sh. Alok Sharma, Chief General Manager (Fire & Safety), IGL Bhawan, Plot No.4, Community Centre, RK Puram, Sector-9, New Delhi-110022.
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building: **Indraprastha Gas Ltd. Retail Outlet (CNG Pump) at CGO Complex, Lodhi Road, New Delhi.**
2. Type of Occupancy : **Hazardous (CNG Pump), 03 Cascades at roof of bldg, 03 Compressor units & 17 Dispensing units**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/CNG/2018/SZ/861 Dated 27.04.2018**
5. Fire Safety directives Letter No. : **F.5(3A)/DFS/CNG/2000/124 Dated 29.03.2000**
6. Date of inspection : **19/03/2021**
7. Name of the Inspecting Officer : **A.D.O. (S.J.)**
8. Name and designation of Officer from the building side : **Sh. Ajay Khatri (DGM Fire & Safety)**
9. Year of Construction : **2000**
10. Applicant's letter received through email Id-ajay.khatri@igl.co.in dated 08/03/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9mtr	12mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	One	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	0.70m	1.25m upto 1 st floor & than 0.80m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	Required	38 Nos	M/R
	• Types	DCP & CO ₂	DCP (75kg)-13, DCP (10kg)- 20, CO ₂ (4.5kg)-05 and Water mist trolley	M/R
	• ISI marking	ISI marked	Provided	M/R

	each floor			
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	Gas & flame	Provided in compressors	MR
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	Required	Technician room	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Co ₂ flooding system			
	• Ground Floor	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A

15	Exit Signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	NA	Provided DG Set	NA
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Co2 flooding system connected through detectors provided in each compressor unit		MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/CNG/2018/SZ/861 Dated 27.04.2018** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
23/3/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

[Signature]
DO(SJ)

[Signature]
Liny
24/03

[Signature]
DFO(SJ)

F.F. please.

[Signature]

F.T. is put up for sign. pl.

[Signature]
BY CFO(SJ)

[Signature]
30/3/2021