

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No.F.6/DFS/MS/SZ/2021/ 217

Dated: 09/04/2021

FIRE SAFETY CERTIFICATE

Certified that the National Co-Operative Union of India located at 3, Siri Institutional Area, August Kranti Marg, New Delhi-110016, comprised of Two Blocks = 1st block (New Building) Basement, GF, Audi (On GF & 1st Floor), & 5 Upper Floors and 2nd block (Old Building) Basement, GF & 5 Upper Floors only, owned / occupied by National Co-Operative Union of India, has already been issued Fire Safety Certificate Vide letter No. F6/MS/DFS/2000/247 dated 08/02/2001 (Old Building), F6/MS/DFS/2001/348 dated 28/02/2001 (New Building) & F6/DFS/MS/2017/SZ/1442 dated 03/01/2017 (for Audi in New Building). The premises was re-inspected by the officers concerned of Fire Service on 22.03.2021 in the presence of Sh. P.S. Dahiya, A.E. (E) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Group-D) with effect from 09/04/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to the compliance of the condition under rule 38 of the DFS rule, 2010.

Issued on 09/04/2021 at New Delhi by


(ATUL GARG)
DIRECTOR
etc

Copy to :-

1. Director (Estate), National Co-Operative Union of India located at 3, Siri Institutional Area, August Kranti Marg, New Delhi-110016.
2. Joint Commissioner of Police (Lic.), PS Defence Colony, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.DelhiGovt.nic.in

1. Name & address of the building: **National Co-Operative Union of India, 3, Siri Institutional Area, August Kranti Marg, New Delhi-110016.**
2. Type of Occupancy : **Mixed Occupancy [Assembly (Audi)+ Business]**
3. Building comprised of : **Two Blocks = 1st block (New Building) Basement, GF, Audi (On GF & 1st F.), & 5 Upper Floors. 2nd block (Old Building) Basement, GF & 5 Upper Floors.**
4. Type of Case : **Renewal**
5. Details of previous NOC : **F6/MS/DFS/2000/247 dated 08/02/2001 (Old Building), F6/MS/DFS/2001/348 dated 28/02/2001 (New Building) & F6/DFS/MS/2017/SZ/1442 dated 03/01/2017 (for Audi in New Building)**
6. Fire Safety directives Letter No. : **F6/MS/DFS/2000/2141 dated 23/11/2000(Old & New Building) & F6/DFS/MS/BP/98/31 dated 05/01/1998 (for Audi in new building).**
7. Date of inspection : **22/03/2021**
8. Name of the Inspecting Officer : **D.O. (S.D.) & A.D.O. (S.J.)**
9. Name and designation of Officer from the building side : **Sh. P.S. Dahiya, A.E.(E)**
10. Year of Construction : **1998**

11. Applicant's letter received through Email ID-ps.dahiya@yahoo.in dated 1/3/21

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtr	15 mtr	MR
	• Gate width	4.5 mtr	5 mtr	MR
	• Width of internal road	6 mtr	6 mtr	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	3 & 2 (Ramps)	3 & 2 (Ramps)	MR
	b. Width of staircases			
	• Upper floors	1.50 m (Each)	1.50 m (Each)	MR
	• Basements	1.50 m (Each)	1.50 m (Each)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.50m (Audi) & 1.00m	1.50m (Final Exit)	MR (Old Case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Ground Floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	20	20	M/R
	• Types	ABC/CO ₂	Provided	M/R
	• ISI marking	Required	Provided	M/R

First - Aid Hose Reels				
	• Total numbers on each floor	3	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke, Beam & Heat	Smoke, Beam & Heat	MR
	• Location of Main Panel	GF	GF	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	All Areas	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	Required in Audi	Provided at stage only	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	3	Provided	MR
	• Hose Box	3	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2850 LPM	2850 LPM	MR
	➤ Head of main pump	70 MH	70 MH	MR
	➤ Number of main pumps	2	2	MR
	➤ Jockey pump out put	240 LPM	240 LPM	MR
	➤ Jockey pump head	70 MH	70 MH	MR
	➤ Standby Pump out put	2850 LPM	2850 LPM	MR
	➤ Standby Pump Head	70 MH	70 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	3,00,000 ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 Ltr.	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	ABC & CO ₂	Provided in electric panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/MS/DFS/2000/247 dated 08/02/2001 (Old Building), F6/MS/DFS/2001/348 dated 28/02/2001 (New Building) & F6/DFS/MS/2017/SZ/1442 dated 03/01/2017 (Audi New Building) renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

S.K. Dua
25/03


Signature of the Inspecting Officer
Name : S.K. Dua
Designation : D.O.(S.D.)

A.K. Jaiswal
29/3/2021

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O.(S.J.)

D.O. (S.D.)

30/3



(S.D.)

[Signature]