

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/SZ/Industrial/2021/ 216

Dated: 08/04/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s Ramayana Handicrafts** located at **E-40/5, Okhla Industrial Area, Phase-II, New Delhi - 110020** comprised of **Basement, ground, Mezzanine, 1st Floor & ½ 2nd Floor** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Industrial/SZ/2018/458 Dated 20/03/2018. The building was re-inspected by the officer concerned of this department on 05/04/2021 in the presence of Sh. Ashok Kumar Gupta and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class – G, Industrial Building** with effect from 08/04/2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 08/04/2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. M/s Ramayana Handicrafts at E-40/5, Okhla Industrial Area, Phase-II, New Delhi – 110020
2. The Executive Engineer (Bldg.) SDMC, Jal Vihar, Lajpat Nagar, New Delhi - 110024

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

1	Name & Address of the Building	M/s Ramayana Handicrafts, F-40-5, Okhla Industrial Area Phase- II, New Delhi 110020.		
2	Type of Occupancy	Industrial (Group - G)		
3	Building Comprised of	Basements, Ground , Mezzanine, First Floor & ½ 2 nd floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Industrial/SZ/2018/458 dated 20/03/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	05/04/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Ashok Kumar Gupta		
10	Year of construction	1982		
11	Applicant letter No.	Outdoor diary no 11640 dated 04-03-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width 	9 mtr	Provided ✓	MR
	<ul style="list-style-type: none"> Gate width 	5 mtr	4.5 mtr ✓	MR (old case)
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors 	2 Nos	Provided	MR
	<ul style="list-style-type: none"> Basement floor 	2 Nos	Provided	MR
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors 	1.2 mtr	1.20 & 0.94 mtr ✓	MR (old case)
	<ul style="list-style-type: none"> Basement floor 	1.2 mtr	1.20 & 1.1 mtr ✓	MR (old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	02 Nos	Provided ✓	MR
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	NA	1 mtr (Final Exit) ✓	NA
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. 	Required	Provided	MR
	<ul style="list-style-type: none"> Sealing of electrical shafts. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire rating of shaft door. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire dampers. 	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement 	30 ACPH	Ex. Fan Provided ✓	MR
	<ul style="list-style-type: none"> Upper floors 	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers 	Required	30 Nos ✓	MR
	<ul style="list-style-type: none"> Types 	ABC / Co2	ABC/ Co2 type	MR
	<ul style="list-style-type: none"> ISI Marking 	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. 	01 at each floor	Provided ✓	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Smoke/Heat	MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Ground floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		All Area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		01 Nos.	Provided	MR
		01 Nos.	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	02 Nos	Provided	MR
		02 Nos	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	2280 LPM	Provided	MR
		60 M	Provided	MR
		01 No	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	450 & 900 LPM	MR
		40 mtr	30 & 40 m respectively	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,00,000 Ltrs	1,00,000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltrs	20,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detection System Panel 	Required	Provided	MR

N/14

	<ul style="list-style-type: none"> Flow Switch Panel PA System Panel Battery backup. Building Floor plans 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any.	Required	02 ABC type fire Extinguisher Near LT Panel	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Industrial/SZ/2018/458 dated 20/03/2018 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please

[Handwritten Signature]

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO (BCP)

DO (SD)

Please spe about point no 13. (Jockey pump & Standby pump)

[Handwritten Signature]

ADO (BCP) - Spoken with ADO (BCP)

- Being old case, Jockey pump & Standby pump is not requized, as the same is mentioned in earlier reports also.

- Submitted please.

F.T. pl. [Handwritten Signature]

Defo (S2)

[Handwritten Signature]

ADO (BCP)

As approved, F.T. letter is ready for your signature

1/14/2014

Dy Cfo/S2

[Handwritten Signature]