

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/Metro/NDZ/2021/ 209

Dated:- 08/04/2021

FIRE SAFETY CERTIFICATE

Certified that the **Shivaji Stadium Airport Metro Station of Airport Metro Express Line, New Delhi** was granted FSC by this department vide letter no. **F6/DFS/MS/metro /2018/NDZ/272 dated 21/02/2018**. The premises was re-inspected by the officer concerned of this department on 26-03-2021 in the presence of Sh. Ravinder (fire officer) & Mr. Dalbir Singh and found that the said metro station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building** with effect from ~~28/04/2021~~ 2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ~~08/04/2021~~ at New Delhi by.



(Dr. S.K Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

Sr. DGM/E & DMRC,
Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Property Development Area at Metro station has already been issued FSC Vide letter no. F6/DFS/MS/DMRC/NDZ/2020/228 dt. 29.6.2020 for Business occupancy at Mezzanine and Concourse level.

INSPECTION REPORT

1. Name & address of the building : Shivaji Stadium Airport Metro Station of Airport
Express Metro Line, New Delhi
2. Type of Occupancy : Assembly Building under Ground Metro Station
3. Type of Case : Renewal
4. Details of previous FSC : F6/DFS/MS/metro//NDZ/2018/231 dated 21/02/2018
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 26/03/2021
7. Name of the Inspecting Officer : Sh. Rajinder Atwal DO/CD &
Sh. Ravinder Singh ADO/CC
8. Name and designation of Officer
from the building side : Sh. Ravinder (Fire Officer) & Sh. Dalbir Singh
9. Year of Construction : 2011
10. Applicant's letter No. : e-mail < pushkar.singh3@gmail.com dated
15.03.2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Required	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	06 mtr.	06 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	03nos (platform to concourse) & 5 nos (concourse to ground level)	03nos (platform to concourse) & 5 nos (concourse to ground level).	MR
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	1.5 mtr.	1.5 mtr. each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace			
	E. Width of corridor	02 mtr.	02 mtr.	MR
	F. Door size	1.50 mtr.	02 & 1.50 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR

N/20

	3) Fire rating of shaft door	Required	Provided	MR
	4) Fire curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	20	23	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	04	04	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	06 mm	06 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	multi sensor	MR
	2) Location of main panel	Concourse	Station (C.R)	MR
	3) Location of repeater panel	Main entry	Each floor	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm	MR
	2) Number of hydrants per floor	04	04	MR
	3) Hose box per floor	04	04	MR
12.	Yard Hydrants			
	1) Total number of hydrants	14 no	14 no	MR
	2) Hose box	14 no	14 no	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	4500 LPM	4500 LPM	MR
	b) Head of main pump	80 mtr	80 mtr	MR
	c) Number of main pump	1 No.	1 No.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	80 m	80 m	MR
	f) Stand by pump output	4500 LPM	4500 LPM	MR
	g) Stand by pump head	80 m	80 m	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A

N/21

	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltrs.	2,00,000 ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.		Open glass lift	
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO2			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/metro/2018/NDZ/272 dated 21/02/2018 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval .

Signature of the Inspecting Officer

[Handwritten Signature]
20/3/21

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

[Handwritten Signature]
30/3/21

Name :- Ravinder Singh
Designation :- ADO (CC)



[Handwritten Signatures]
Dy. Chf. (MS2)
A. Kumar
11/4/21

[Handwritten Signatures]
DO (CD)
A.T. M.

[Handwritten Note]
3/4/21 A - submittance RTI put up for ICD review