

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/Bldg/2021/SZ/ 243

Dated: 28 / 04 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **Headquarter building of Central Information Commission (CIC)** situated at **Old JNU Campus, Baba Gangnath Marg, New Delhi 110067** comprised of **02 Basements Ground Plus Four Upper Floor** was issued FSC by this department vide letter No. F6/DFS/MS/Bldg/SZ/2018/349 dated 05/03/2018. The premises was re-inspected by the officer concerned of this department on 08/04/2021 in the presence of Mr. Rohit Rajput (Project) PE (Civil) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Business Building** as above with effect from 28 / 04 / 2021 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 28 / 04 / 2021 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service


Copy to: -

1. The Central Information Commission (CIC) Building Baba Gangnath Marg, New Delhi – 67
2. The Executive Engineer (Bldg) HQ, South MCD, 8th Floor SPM, Civic Centre, Minto Road, New Delhi 110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Central Information commission, HQ Building, Old JNU Campus, Baba Gang Nath Marg, Munirka, New Delhi		
2	Type of Occupancy	Business Building		
3	Building Comprised of	02 Basement, Ground + Four Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Bldg/S7/2018/349 dated 05/03/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/2017/BP/255 Dated 14/08/2017		
7	Date of Inspection	08/04/2021		
8	Name of the Inspecting Officers	Sri. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Rohit Rajput (Project) PE (civil) NSL		
10	Year of construction	2005		
11	Applicant letter No.	Gmail Dated 25/03/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/ NBC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	24 mtr	MR
	• Gate width	06 mtr	06 mtr	MR
	• Width of internal road	06 mtr	5.50 to 6 mtr	MR (old case)
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	1. Upper floors	02 No's	04 Provided	MR
	2. Basement floor	2 No's	02 Nos + 1 ramp	MR
	b. Width of Staircase			
	1. Upper floors	1.50 mtr	2 m x 3 & 1.5 m	MR
	2. Basement floor	1.50 mtr	2 m, 1.5 m & 4 m ramp	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace	Required	04 Provided	MR
	e. Width of corridor	1.80 mtr	Provided	MR
	f. Door size	1.50 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	12 ACPH	Provided	MR
	• Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	50	58 Nos Provided	MR
	• Types	ABC / Co2	Provided	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 at each floor	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7	Automatic Fire Detection & Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Heat & Smoke	MR
		Required	Provided at GF	MR
		NA	N/A	NA
		Required	Provided	MR
		All area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors (on 3rd floor) Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		02	Provided	MR
		02	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	04	Provided	MR
		04	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	➤ Discharge of main pump.	2280 LPM	Provided	MR
	➤ Head of main pump.	80m	Provided	MR
	➤ Number of main pumps.	01	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	80 m	Provided	MR
	➤ Standby Pump output.	2280 LPM	Provided	MR
	➤ Standby Pump head.	80 m	Provided	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	2,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room.			

2/18

	• Detector System Panel.	Required	Provided	MR
	• Flow Switch Panel.	Required	Provided	MR
	• PA system Panel.	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Co2/Inert gas flooding system found provided	MR
<p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Bldg/SZ/2018/349 dated 05/03/2018, renewal under rule 35 (6) of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				

14/15/14

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

DO (SD)

19/04

Defto (SD)

19/14

C.A.O.

21/4



Handwritten signature and text: 20/4/21, 153, and other illegible marks.

Handwritten signature at the bottom.