

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/School/2021/SZ/ 329

Dated: 16.4.2021

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Senior Secondary School**, located at **J. J Colony, Madanpur Khadar, New Delhi-110076** comprised of Ground plus three upper floor was issued FSC by this department vide letter No. F6/MS/DFS/2017/SZ/1538 dated 27/10/2017. The premises was re-inspected by officer concerned by this department on 02/04/2021 in the presence of Ms. Anita Kumari (Principal) of the school and observed that the school premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational**" Group-B (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 16/4/21/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Govt. Girls Senior Secondary School, J. J Colony, Madanpur Khadar, New Delhi-110076
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Basement shall be used strictly in accordance with provisions of BBL-1983.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

1	Name & Address of the Building	Govt Girls Senior Secondary School, J.J Colony, Madanpur Khadar, New Delhi-110076 (ID-1925348)		
2	Type of Occupancy	Educational Building "Group-B"		
3	Building Comprised of	New Bldg-Ground+ 3 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/1538 dated 27/10/2017		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	02/04/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms Anita Kumari (Principal)		
10	Year of construction	2016	Old bldg comprised of GF only demolished	
11	Applicant letter No.	Gmail dated 18/03/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC/ BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	6 mtr ✓	MR
	• Gate width	4 mtr	4 mtr ✓	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	04 Nos	04 Nos	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floor	1.50 mtr	1.80 mtr each	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	02 Provided ✓	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	N/A	NA	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	24 No's	36 No's ✓	MR
	• Types	ABC / CO ₂	ABC-20, / CO ₂ -10	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	04 at each	Provided	MR
	• Length of hose-reel hose.	30 m	30 m	MR
	• Nozzle Diameter	5 mm	5 mm ✓	MR
7	Automatic fire detection & alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A

10. Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11. Internal Hydrants.				
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of Hydrant per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
12. Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13. Pumping arrangements.				
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM	450 LPM at each	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40 mtr	40 mtr each	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14. Captive water storage for Fire Fighting.				
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 ltrs	10,000 ltrs	MR
15. Exit Signage.		Required	Provided	MR
16. Provisions of Lifts.				
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17 Standby Power Supply		N/A	N/A	N/A
18. Refuge Area				
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19. Fire Control Room.				
	<ul style="list-style-type: none"> Detector System Panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow Switch Panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA system Panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Battery backup 	N/A	N/A	N/A

N/20

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/School/2017/SZ/1538 dated 27/10/2017 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

12/4/2021

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

DO (SD)

12/4/2021

DFA (SD)

[Signature]

12/4

~~*ADO (BCP)*~~

As approved, F-1 letter is put up for your signature pl

12/4/2021

DFA (SD)

[Signature]

M.S. cell