

C/35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.F6/DFS/MS/School/NDZ/2021/ 336

Dated: 19/04/2021

FIRE SAFETY CERTIFICATE

Certified that the **Ramjas Girls Sr. Sec. School & Ramjas Primary School** located at **Daryaganj, Delhi-02**, comprised of **Ground plus + 1 upper floor (ground floor – Ramjas Sr. Sec. School, 1st floor – Ramjas Primary School)** was granted Fire Safety Certificate by this department vide letter No- F6/DFS/MS/2018/School/1677 dated 17.07.2018. The school building was re-inspected by Assistant Divisional Officer (SPM) from this department on 12.04.2021 in the presence of Shri Kaushal Sharma & Shri Pawan Sharma (from both the schools respectively) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No..F-16/Estate/Fire safety/2011/ 3298 to 3398 dated 01.03.2011 issued by the Director of Education and the building (**Ground floor + 01 upper floor only**) is fit for occupancy of Group B "Educational Building" with effect from 19/04/2021 renewed for a period of three years, subject to conditions printed below.

Issued on 19/04/2021 at New Delhi by


16/4/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

1. The Principal, **Ramjas Girls Sr. Sec. School** located at **Daryaganj, Delhi-02**
2. The Principal, **Ramjas Primary School** located at **Daryaganj, Delhi-02**
3. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi

o/c 
15/4

Condition for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	Ramjas Girls Sr. Sec. School and Ramjas Primary School, Daryaganj, Delhi – 02.		
2	Building is comprised of	Ground + 01 upper floor. Ground floor – Ramjas Girls Sr. Sec. School. 1 st floor – Ramjas Primary School.		
3	Type of Occupancy	Educational		
4	Type of Case	Renewal		
5	Details of Previous FSC	F6/DFS/MS/2018/Schools/NDZ/1677 dated 17.07.2018.		
6	Fire Safety direction letter No	F-16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011		
7	Date of Inspection	12.04..2021		
8	Name of the Inspecting Officers	ADO (SPM) Rajesh Kumar Shukla		
9	Name of the designation of Officer from the building side	Shri Kaushal Sharma (Head Clerk) & Shri Pawan Sharma (Manager)		
10	Year of Construction	1961 & 1984 respectively.		
11	Applicant's letter No	Email dated 08.04.2021.		
S.No	Fire Safety standards as per Circular no. F-16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 meters	06 meters	MR
	Gate width	04 meters	04 meters	MR
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	A. Number of Staircases			
	a. Upper Floor	02 nos.	02 nos.	MR
	b. Basement	NA	NA	NA
	B. Width of Staircases			
	a. Upper Floor	150 cms. 75 cms	165 cms, 95 cms	MR
	b. Basement	NA	NA	NA
	C. Protection of exits			
	a. Fire check door	NA	NA	NA
	b. Pressurization	NA	NA	NA
	D. No. of continuous staircases to terrace	01	02	MR
	E. Width of Corridor	150 cms	234 cms	MR
	G. Door size	1 meter	1 meter	MR
3	Compartmentation			
	A. Fire check door	NA	NA	NA
	B. Sealing of electrical shafts	NA	NA	NA
	C. Fire rating of shaft door	NA	NA	NA
	D. Water curtain	NA	NA	NA
	E. Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	A. Basement	NA	NA	NA
	B. Upper floor	Natural/ mechanical	Natural	MR

(Signature)

5.	Fire Extinguisher			
	A. Total numbers	10 nos.	12 nos.+ 08 nos.	MR
	B. Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C. IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	A. Total numbers of each floor	NA	02 nos.	NA
	B. Length of hose reel hose	NA	Provided	NA
	C. Nozzle diameter	NA	Provided	NA
7	Automatic fire detection and alarming system.			
	A. Type of detectors	NA	NA	NA
	B. Location of main panel	NA	NA	NA
	C. Location of repeater panel	NA	NA	NA
	D. Alternate source of power	NA	NA	NA
	E. Hooters	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public address System.			
		NA	Provided	NA
10	Automatic Sprinkler System.			
	A. Basement	NA	NA	NA
	B. Upper Floor	NA	NA	NA
	C. Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	A. Size of riser/down-comer	NA	NA	NA
	B. Number of hydrants per floor	NA	NA	NA
	C. Hose Box	NA	NA	NA
12	Yard Hydrants.			
	A. Total number of hydrants	NA	NA	NA
	B. Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	A. Ground Level			
	a. Discharge of main Pump	NA	NA	NA
	b. Head of Main Pump	NA	NA	NA
	c. Number of main pumps	NA	NA	NA
	d. Jockey pump out put	NA	NA	NA
	e. Jockey pump head	NA	NA	NA
	f. Standby pump out put	NA	NA	NA
	g. Standby pump Head	NA	NA	NA
	h. Auto Starting /Manual stopping	NA	NA	NA
	i. Pump House Access	NA	NA	NA
	B. Terrace Level			
	a. Discharge of pump	NA	360 lpm	NA
	b. Head of the Pump	NA	25 meter	NA
	c. Power supply	NA	Provided	NA
	d. Auto Starting of pump	NA	NA	NA

8/1

14	Captive Water Storage for Fire Fighting.			
	A. Underground tank capacity	NA	NA	NA
	B. Draw-off connection	NA	NA	NA
	C. Fire service inlet	NA	NA	NA
	D. Access to tank	NA	NA	NA
	E. Overhead Tank capacity	NA	5000 litres	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts:			
	A. Pressurization of Lift Shaft	NA	NA	NA
	B. Pressurization of Lift lobby	NA	NA	NA
	C. Communication in lift car	NA	NA	NA
	D. Firemen's grounding switch	NA	NA	NA
	E. Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	A. Total area	NA	NA	NA
	B. Location	NA	NA	NA
19	Fire Control Room			
	A. Detector system panel	NA	NA	NA
	B. Flow switch panel	NA	NA	NA
	C. PA system panel	NA	NA	NA
	D. Battery backup	NA	NA	NA
	E. Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		Fire buckets	MR

MR – meeting requirement, NMR – Not Meeting Requirement, NA – Not Applicable,

The fire safety systems installed in the building were inspected, checked and tested randomly and were found to be functional at the time of inspection and the school management has complied with the fire safety arrangements as required in the previous inspection report.

In view of the deemed compliance of minimum standards of fire safety required under Rules, it is recommended to renew the FSC to both the schools issued vide letter no. F6/DFS/MS/2018/Schools/NDZ/1677 dated 17.07.2018.

Accordingly DFA of FSC is put up for approval please.

[Signature]
13/4/2022

Signature of the Inspecting Officer
Name Rajesh Kumar Shuka
Designation: ADO (SPM)

[Signature]
13/4



[Signature]
13/4
Dy. Chf. (AD2)

F.T. pl.
[Signature]
13/4/21

ADOC(SPM) 29 is put up pls