

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/Hotel/2021/254

Dated: 12/05/2021

FIRE SAFETY CERTIFICATE

Certified that the Ware House (Delhi Cargo Service Center Pvt. Ltd.) at Cargo Terminal-II (Adjacent to existing ATC, Gate-1), Air Cargo Complex, IGI Airport, New Delhi-110037, Comprised of Ground Floor (Shed) only owned / occupied by Delhi Cargo Service Center Pvt. Ltd. was issued FSC by this office vide letter No. F6/DFS/MS/H/SZ/2018/2070 Dated 10/09/2018. The premises was re-inspected by the officer concerned of this department on 31/03/2021 in the presence of Sh. Deepak Karki and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Storage" (Group-H) (Storage) with effect from 12/05/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 12/05/2021 at New Delhi.



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Authorized Signatory, DCSC Pvt. Limited, Cargo Terminal-2, Gate No.-6, IGI Airport, New Delhi-110037.
2. The CEO, DIAL, Udaan Bhawan, IGI Airport, New Delhi-110037.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

- INSPECTION REPORT**
1. Name & address of the building: **Ware House (Delhi Cargo Service Center Pvt. Ltd.) at Cargo Terminal-II, Adjacent to existing ATC, Gate-1), Air Cargo Complex, IGI Airport, New Delhi-110037.**
 2. Type of Occupancy : Storage (Group-H)
 3. Building comprised of : Ground Floor (Shed)
 4. Type of Case : Renewal
 5. Details of previous NOC : F6/DFS/MS/H/SZ/2018/2070 Dated 10/09/2018
 6. Fire Safety directives Letter No. : F6/DFS/MS/BP/2017/364 dated 21/12/2017
 7. Date of inspection : 31/03/2021
 8. Name of the Inspecting Officers : A.D.O. (S.J.)
 9. Name and designation of Officer from the building side : Sh. Deepak Karki
 10. Year of Construction : 1918
 11. Applicant's letter received through email ID-Pradeep.Yogi@gmail.com dated 08/03/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC/Old Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA		
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.50m x 14	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Ground /Upper floors	12 ACPH	Annex. M	MR
5.	Fire Extinguishers			
	• Total numbers	60	Provided	MR
	• Types	ABC/CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR



	each floor			
	• Length of hose reel hose	30Mtr.	30Mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke / Heat / Beam	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	NA	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Low Hazard as per clause 3.1.2 of UBBL-2016 (Annexure-XIII)	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	17	Provided	MR
	• Hose Box	17	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	14	Provided	MR
	• Hose Box	14	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	1620 LPM	Provided	MR
	➤ Head of main pump	70m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	1620 LPM	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Manual gas flooding / linear heat sensing tubes with CO ₂ cylinder in HT & LT Panels	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring have also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/H/SZ/2018/2070 Dated 10/09/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

A.K.
6/4/2021

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (S.J.)

~~DO (SD)~~

Signature
07/04/21

Defo (S.J.)

F. T. pl.

Signature

Signature F.T. is added for sign. pl.