

G-108

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**


No: F6DFS/MSMN/2021/ EH/112

Dated: 5/3/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Air bar & Lounge located at 1/83, 2nd & 3rd floor Club Road, Punjabi Bagh, New Delhi - 110026 in a building comprised of Basement, Ground & three upper floors, owned/Occupied by M/s Air bar & Lounge. Fire safety certificate of Second floor was already issued by this department Vide Letter No. F.6/DFS/MS/EH/WZ/195 dated 31/12/2020 and third floor is now newly added. The premises was re - inspected by the officer concerned of this department on 17/04/2021 in the presence of Sh. Sujit Mishra (Manager) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said floor is fit for occupancy class "Assembly" Group-D(for 2nd & 3rd floor Only) with effect from 05/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/03/2021 at New Delhi.


(Atul Garg)
Director,
Delhi Fire Service

Copy to:-

1. Sh. Sujit Mishra (Manager) Air Bar & Lounge 1/83, 2nd and 3rd Floor Club Road, Punjabi Bagh, New Delhi - 110026.
2. Dy. Health Officer (West Zone), South Delhi Municipal Corporation, Rajouri Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. Basement shall be used as per building bye laws.
6. Use of terrace above third floor for restaurant purpose is not allowed. If it is used, FSC is null & void.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The Owner/ Occupier shall apply for the renewal of this Fire safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six month prior to its expiry.

2. Type of Occupancy : Assembly (Class-D)
 3. Type of Case : New
 4. Details of previous NOC : F6/DFS/MS/EH/2013/1143 dated-30-10-2013.
 Issued to Buzz (Next Level Food and Beverages
 Pvt. Ltd. For 2nd floor)
 5. Fire Safety directives Letter No. : Nil
 6. Date of inspection : 17/04/2021
 7. Name of the Inspecting Officer : Sh. Sunil Chawdhary, DCFO (WZ), M.K.
 Chattopadhyay DO (West), Sh. Sarabjeet Singh
 ADO (MN)
 8. Name and designation of Officer
 from the building side : Sh. Sujit Mishra (Manager)
 9. Year of Construction : 1996
 10. Applicant's letter No. : Online Application 2021040712449 Dated 08/04/2021

The said restaurant is located at second & third floor in a building comprised of basement, ground plus three upper floor.(Second floor is already renewed Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/2020/195 dated 31/12/2020 and third floor is under consideration.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	4.5 mts	On main road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	01	NA
	b. Width of staircases			
	• Upper floors	2mts & 1.5 mts	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	6 Nos	Provided	MR
	• Types	ABC, CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR

	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required in 2 nd & 3 rd floor	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump	70 mt	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 mt	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided (Instead of D.G. pump, alternate electric pump provided connected with DG set)	MR
	➤ Standby Pump Head	70 mt	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	1,00,000 ltrs	Provided (Certificate of Regt. Architect attached)	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15000 lts	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			

	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: In pumping arrangements, One Electrical driven Standby pump of capacity 2280 LPM instead of D.G. pump is provided. One certificate from registered architect, Mr Vaibhav Babbar for underground water tank having capacity 01lakh lts is also provided and it may be accepted if allowed.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Sunil Chawdhary
DCFO(WZ & SZ)



M.K. Chattopadhyay
DO(West)



Sarabjeet Singh
ADO(MN)

03/05/2024 C.F.O. Day off


~~Director / my / 3/05/2021~~

FT Pls

DO/Wed

Sir, F.T is put up for your sig. pls.

Director / my / 03/05/2024


03/05/2024