

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/Hospital/2021/SZ/ 228

Dated: 20/04/2021

FIRE SAFETY CERTIFICATE

Certified that the **R G Stone Urology and Laparoscopy Hospital, F-12, East of Kailash, New Delhi – 110065**, comprised of **Basement, ground plus Three upper floors** has already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Hospital/SZ/2018/457 dated 20/03/2018. The Hospital was re-inspected by officer concerned of this department on 07/04/2021 in the presence of Sh. Avinash Ojha (Chief Executive officer) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-C Institutional (Hospital)** as above with effect from 20/04/2021 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 20/04/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Sh. Avinash Ojha (Chief Executive officer) R G Stone Urology and Laparoscopy Hospital, F-12, East of Kailash, New Delhi – 110065
2. Executive Engg. (Bldg) SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	R.G Stone Urology and Laparoscopy Hospital, F-12, East of Kailash, New Delhi-1100765		
2	Type of Occupancy	Institutional building, "Group-C" (Hospital)		
3	Building Comprised of	Basement, Ground & Three Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Hospital/SZ/2018/457 dated 20-03-2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	07/04/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Avinash Ojha (Chief Executive officer)		
10	Year of construction	1984		
11	Applicant letter No.	Gmail dated 18-03-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	9 mtr	MR
	• Gate width	5 mtr	About on road	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	2 m	2 m & 1.23 m	MR
	➤ Basement floor	1.25 m	1.5 m & 1.12 m	MR
	c) Protection of exits			
	➤ Fire check door	Required in basement	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	02 Nos Required	02 Nos	MR
	e) Width of corridor	1.5 m	1.63 m	MR
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	Required in basement	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	Required	37 Nos	MR
	• Types	ABC/W.CO2	ABC, CO2 & W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	Ground floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	All area	MR

N/16

8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	01 Provided	MR
	<ul style="list-style-type: none"> Hose box. 	Required	01 Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	NA	01 Nos	NA
	<ul style="list-style-type: none"> Hose box. 	NA	01 Nos	NA
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	1620 LPM	1620 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of main pump. 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	one	one	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	1620 LPM	1620 LPM	MR
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump house access. 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	-NA-	450LPM	-NA-
	<ul style="list-style-type: none"> ➤ Head of pump. 	-NA-	46m	-NA-
	<ul style="list-style-type: none"> ➤ Power supply. 	-NA-	Provided	-NA-
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	-NA-	Provided	-NA-
14	Captive water storage for fire fighting.	On standalone platform at 1 st floor level		
	<ul style="list-style-type: none"> Underground tank capacity. 	50,000 Ltrs	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	Required	Provided	MR
	<ul style="list-style-type: none"> Flow switch panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA system panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Battery backup. 	Required	Provided	MR
	<ul style="list-style-type: none"> Building floor plan. 	Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Two Co2 Flooding system is provided near electric Panels	MR

N

The Fire protection systems provided in the building were checked/ tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/Hospital/SZ/2018/457 dated 20-03-2018 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Handwritten signature
8/4/2021

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~Recd. m 13/04/21~~

~~DO (SD)~~

~~*Handwritten signature*~~
13/04/21

~~Dy. CFO (SZ)~~

~~*Handwritten signature*~~

~~ADO (BCP)~~

As approved, F.T. letter is put up for
your signature @

~~16/4~~
19/4

~~*Handwritten signature*~~

MS. CFO