

C/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / School/WZ/2021/ 344

Dated: 22/04/2021

FIRE SAFETY CERTIFICATE

Certified that the **Adarsh Public School** located at **Harewali, Delhi-110039** comprised of **Ground floor only** owned/ occupied by the **Adarsh Public School** was issued FSC by this department vide letter No **F6/DFS/MS/2018/School/WZ/978** dated **09.05.2018**. The building/premises was inspected by the officer concerned of this department on **15.04.2021** in the presence of **Sh. Ganga Ram (Secretary)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ..22/04/2021.. for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...22/04/2021.. at New Delhi


(Sunil Chaudhary)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Adarsh Public School, Harewali, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Adarsh Public School, Harewali, Delhi-110039.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Building Comprised : Ground Floor Only
5. Details of previous NOC : F.6/DFS/MS/2018/School/WZ/978 Dated: 09/05/2018
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 15/04/2021
8. Name of the Inspecting Officers : ADO(BW)
9. Name and designation of officers from the building side : Sh. Ganga Ram (Secretary)
9. Year of Construction : 2002
10. Applicant's letter No. : APS/2021/29 dated 27.03.2021

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1m double door	MR

Handwritten signature

3	Compartmentation.			NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
4	Smoke Management System.			NA	NA	NA
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA		
5	Fire Extinguishers			04nos	06nos	MR
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	ABC/CO2	ABC-06nos	MR		
		ISI Marked	Yes	MR		
6	First-Aid Hose Reels.			NA	NA	NA
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA		
		NA	NA	NA		
7	Automatic fire detection and alarming system.			NA	NA	NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		
MOEFA	NA	NA	NA			
8	Public Address System.			NA	NA	NA
9	Automatic Sprinkler System.			NA	NA	NA
10	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA		
		NA	NA	NA		
		NA	NA	NA		

Ans

11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		14	Captive Water Storage for fire fighting.	
<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
NA	NA	NA		
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	N/A	N/A	N/A
		N/A	N/A	N/A

Q

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended for renewal of fire safety certificate issued vide this department letter no. F.6/DFS/MS/2018/School/WZ/978 dated 09.05.2018.

*File
1500 (BW)
16/4/21*

Signature of the Inspecting Officer
Name :- Rajeev Kumar Sinha
Designation:- ADO(BW)

Do (WZ)

16/04/2021

Dy Cfo (S2 & WZ)

F.T.

*As approved F.T letter is put up for signi
Please*

16/4/21

Dcfo (S2 & WZ)

ms.cdf