

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO.F6/DFS/MS/2021/CNG | 246

Dated: 06/05/2021

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Filling Station (IGL), located at Sector-22, Rohini, Delhi, comprised of Ground + One upper floor owned / occupied by Indraprastha Gas Limited was granted NOC by this department vide letter no . F.6/DFS/MS/2018/CNG/825 dated: 24.04.2018 The premises was re-inspected by officer concerned of this department on 30.03.2021 in the presence of Mr. Shivam Gupta (Dy. Manrager) and found that the premises have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises is fit for occupancy CNG Filling Station Group 'J' with effect from 06/05/2021 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Issued on 06/05/2021 at New Delhi by

  
(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:- 01123414250

**Copy to:**

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Center, R.K. Puram, Sect-9, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1<sup>st</sup> Floor, Police Station, Defense Colony, Delhi

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule/s/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule/s/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT****Gr. + One Upper floor**

1. Name & address of the building : CNG Filling Station (IGL), at Sector-22, Rohini, Delhi-85
2. Type of Occupancy : CNG Filling Station **Group 'J'**
3. Type of Case : Renewal **(Gr. + 1)**
4. Details of previous NOC : F.6/DFS/MS/2018/CNG/825 dated: 24.04.2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 30.03.2021
7. Name of the Inspecting Officers : A.K.Sharma ADO,Rohini
8. Name and designation of officers  
from the building side : Sh. Shivam Gupta (Dy. Manager)
9. Year of Construction : 2010
10. Applicant's letter No. : Online e-mail dated 05.03.2021


---	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Required	30m	MR
	• Gate width	N.A	N.A	N.A
	• Width of internal road	N.A	N.A	N.A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>	—	—	—
	• Upper Floors	Required	Provided	MR
	• Basements	N.A	N.A	N.A
	<b>b. Width of staircases</b>	—	—	—
	• Upper Floors	1.25 mtr	1.25 mtr	MR
	• Basements	N.A	N.A	N.A
	<b>c. Protection of exits</b>	—	—	—
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	<b>d. No. of continuous staircases to terrace</b>	N.A	N.A	N.A
	<b>e. Width of Corridor</b>	N.A	N.A	N.A
	<b>f. Door Size</b>	1.0m	1.0m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N.A	N.A	N.A
	• Sealing of electrical shafts	N.A	N.A	N.A
	• Fire Rating of shaft door	N.A	N.A	N.A
	• Water Curtain	N.A	N.A	N.A
	• Fire Dampers	N.A	N.A	N.A
4	<b>Smoke Management System.</b>			

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	N.A	N.A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	09	17nos.	M.R
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/CO2	10 trolley- 75kg.	M.R
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	07-DCP YES	M.R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	N.A	N.A
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	N.A	N.A
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	N.A	N.A	N.A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N.A	N.A	N.A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.A	N.A	N.A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.A	N.A	N.A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.A	N.A	N.A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N.A	N.A	N.A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			

	➤ Discharge of pump	N.A	N.A	N.A
	➤ Head of the pump	N.A	N.A	N.A
	➤ Power Supply	N.A	N.A	N.A
	➤ Auto Starting of pump	N.A	N.A	N.A
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N.A	N.A	N.A
	➤ Draw-off connection	N.A	N.A	N.A
	➤ Fire service inlet	N.A	N.A	N.A
	➤ Access to tank	N.A	N.A	N.A
	• Overhead Tank capacity	N.A	N.A	N.A
15	<b>Exit Signage.</b>			
		—	—	—
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17	<b>Standby power supply</b>			
		N.A	N.A	N.A
18	<b>Refuge Area.</b>			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N.A	N.A	N.A
	• Flow Switch Panel	N.A	N.A	N.A
	• PA System Panel	N.A	N.A	N.A
	• Batter backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & CO2 flooding system found provided.		M.R
21	<b>DCP Spray System for cascade</b>	Provided		MR

The fire protection systems provided in the building premises were test checked and found functional at the time of inspection.

in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the DFS rules of NOC issued vide letter no. F.6/DFS/MS/2018/CNG/825 dated: 24.04.2018, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

  
 Signature of the Inspecting Officer  
 Name Ajay Kumar Sharma  
 Designation ADO(Rohini)