

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**


No. F.6/DFS/MS/CNG/2021/SZ/241

Dated: 28/04/2021

FIRE SAFETY CERTIFICATE

Certified that **CNG Filling Station** located at **Nelson Mandela Marg, New Delhi** comprised of ground floor only owned/occupied by M/s Indraprastha Gas Limited, was granted FSC by this department vide letter no. F6/MS/DFS/CNG/2018/SZ/1014 Dated 10/05/2018. The premise was re-inspected by the officer concerned of this department on 14.04.2021 in the presence of Mr. Raj Kumar Dutt (Manager) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Storage (CNG Pump) as above with effect from 28/04/2021 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 28/04/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Joint C.P (Lic.) First Floor, PS Defence Colony, New Delhi 110049.
2. Sh. Ajay Khatri, DGM-(Fire & Safety) (IGL) LGL Bhawan, Plot No 4, Community Centre, R. K Puram, Sector- 09, New Delhi 110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

1	Name & Address of the Building	CNG Station at Nelson Mandela Marg, New Delhi (Indraprastha Gas Ltd, Retail outlet)		
2	Type of Occupancy	Hazardous "Group -J (CNG Pump)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/CNG/2018/SZ/1014 Dated 10/05/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14-04-2021		
8	Name of the Inspecting Officers	Mr. Rajesh Kumar (ADO BCP)		
9	Name & Designation of Officers from the building side	Mr. Raj Kumar Dutt (Manager)		
10	Year of construction	2002		
11	Applicant letter No.	Gmail Dated 12-04-2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width 	09 mtr	Provided	MR
	<ul style="list-style-type: none"> Gate width 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basement floor 	-NA-	-NA-	-NA-
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basement floor 	-NA-	-NA-	-NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	Required	Provided 0.70 m	MR
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sealing of electrical shafts. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire rating of shaft door. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire dampers. 	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers 	Required	30 Nos	MR
	<ul style="list-style-type: none"> Types 	ISI Marked	DCP/75 kg- 4, DCP/10kg - 20 & CO ₂ - 06	MR
	<ul style="list-style-type: none"> ISI Marking 		Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Length of hose-reel hose. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Nozzle Diameter 	-NA-	-NA-	-NA-


	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Gas & Flame	Provided in compressors	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. Terrace Level ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	No Smoking signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	NA	Provided (DG Set)	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-






19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	Co2 flooding system connected through detectors provided in each compressor unit	MR

“No Smoking” Sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.


The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/MS/DFS/CNG/2018/SZ/1014 Dated 10/05/2018 under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for perusal and signature please.


 Signature of the Inspecting Officer
 Name: Mr. Rajesh Kumar
 Designation: ADO (BCP)

DO (SD)






~~ADO R/P,~~
 As approved, F.T. letter is put up for
 your signature pl


 1/14
 23/5

