

C-48

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021/ School/WZ/ 339

Dated: 22/4/21

**FIRE SAFETY CERTIFICATE**

Certified that the **DAV Centenary Public School (School ID-1310280)** located at **Sector B/4,Pkt-5, DDA Project, Narela, Delhi-110040** comprised of **Ground+03 upper floors** owned/occupied by **DAV Centenary public School** was issued fire safety certificate **vide letter no. F-6/DFS/MS/School/2017/471 Dated-21/03/2018**. The premises was inspected by the officer concerned of this department on 15/04/2021 in the presence of Sh. Parveen Kumar (Manager) and observed that all the fire prevention and fire safety arrangements provided in the building/premises found in good working condition. The building/premises have therefore deemed complied with Director of Education, Circular No. 262-362 dated 17/01/2005 and that the building / premises is fit for occupancy under **Group B (Educational)** with effect from 22/4/21 for a period of **three years**, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on 22/4/21 at New Delhi by

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
(WEST ZONE)

Copy to-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.
2. The Principal, DAV Centenary Public School, Sec-B/4, Pocket-5, DDA Project, Narela, Delhi-110040.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

2. Type of Occupancy : Educational  
 3. Building Comprised : Ground + Three Upper floors  
 4. Type of Case : Renewal  
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/School/2018/471 Dated-21/03/2018  
 6. Fire Safety directives letter No : DOE Circular Dated 17/01/2005  
 7. Date of inspection : 15/04/2021  
 8. Name of Inspecting Officer : ADO (BW)  
 9. Name and designation of officers  
 From the building side : Sh. Parveen ( Manager)  
 10. Year of Construction : 1995-96  
 11. Applicant's letter No. : E Mail id , Dated-26/03/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular Dt. 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0 m	13.5 m	MR
	• Gate width	5 m	5 m	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02+ 01 ramp	MR
	• Basements(small basement)	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	1.35 m×2 & 1 ramp of 1.48 m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	1.10 m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	32 nos	32 nos	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA

	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> </ul>	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	01	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	01	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> </ul> </li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180 lpm	180 lpm	MR
		40 m	40 m	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> </ul> </li> <li>Auto Starting of pump</li> </ul>	-	-	-
		450 lpm	450 lpm × 02	MR
		40 m	40 m	MR
		Required	Provided	MR
		-	-	-
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20000 ltrs	5000 ltrs × 4	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	NA	NA	NA

18.	<b>Refuge Area.</b> ➤ Total Area ➤ Location	NA	NA	NA
		NA	NA	NA
19.	<b>Fire Control Room</b> • Detector System Panel • Flow Switch Panel • PA System Panel  • Battery backup  • Building Floor Plans	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended for renewal of Fire Safety Certificate, under rule 35 of the Delhi Fire Service Rules 2010.

*(Signature)*  
ADO (B/W)  
16/4/21

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

*(Signature)*  
Do (B/W)

*(Signature)*  
16/04/2021

*(Signature)*  
Dy cfo (S2/BW2)

*(Signature)*  
F.T.

*(Signature)*  
A DO/BW As approved F.T letter is put up for signature

*(Signature)*  
ADO (B/W)  
16/4/21

*(Signature)*  
Dcfo (S2/BW2)

*(Signature)*