

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2021 / 348

Dated: 27 / 4 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Devraji Narayan Public School** located at **Plot no-12, E-block, Swami Shradha Nand Colony, Bhalaswa Dairy, Delhi-110086** comprised of **Ground + One upper floor only** owned/occupied by the **Devraji Narayan Public School** was granted FSC by this department vide letter No. **F6 /DFS /MS /2017/School/WZ/1468 dated 09.10.2017**. The premises was re-inspected by the officer concerned of this department on **12.04.2021** in the presence of **Sh. V.S. Chauhan (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from **27/4/21**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **27/4/21**..... at New Delhi

  
(Atul Gang)  
Director  
Ph:-011-23414000  


Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Manager, Devraji Narayan Public School, Plot no-12, E-Block, Swami Shradha nand Colony, Bhalaswa Dairy, Delhi-110086.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : Devraji Narayan Public School, Pot no-12, E-block, Swami Shradha Nand, Colony, Bhalaswa Dairy Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground+ One Upper Floor)
4. Details of previous NOC : F.6/DFS/MS/2017/School/WZ/1468 Dated: 09.10.2017
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 12.04.2021
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. V.S. Chauhan (Manager)
9. Year of Construction : 2004
10. Applicant's letter No. : Online E-mail ID dated 08.03.2021

Plot Area-1200 sq.yard

Covered Area:400sq.yard

Nos of student—270nos,

class rooms –10 nos

| Minimum Standards on fire prevention and fire safety U/R 33 |  | Circular of Director of Education | Provided at site | Remarks MR/NMR |
|---|--|-----------------------------------|------------------|----------------|
| 1   | <b>Access to building</b>  |                                   |                  |                |
|   | <ul style="list-style-type: none"> <li>Road width</li> </ul>                   | 06m                               | 06m              | MR             |
|   | <ul style="list-style-type: none"> <li>Gate width</li> </ul>                   | 4.5m                              | 4.5m             | MR             |
|   | <ul style="list-style-type: none"> <li>Width of internal road</li> </ul>       | NA                                | NA               | NA             |
| 2   | <b>Number, Width, Type &amp; Arrangement of Exits</b>                          |                                   |                  |                |
|   | a. Number of staircases  |                                   |                  |                |
|   | <ul style="list-style-type: none"> <li>Upper Floors</li> </ul>                 | 02                                | 02               | MR             |
|   | <ul style="list-style-type: none"> <li>Basements</li> </ul>                    | NA                                | NA               | NA             |
|   | b. Width of staircases   |                                   |                  |                |
|   | <ul style="list-style-type: none"> <li>Upper Floors</li> </ul>                 | 1.5m                              | 1.5m each        | MR             |
|   | <ul style="list-style-type: none"> <li>Basements</li> </ul>                    | NA                                | NA               | NA             |
|   | c. Protection of exits   |                                   |                  |                |
|   | <ul style="list-style-type: none"> <li>Fire check door</li> </ul>              | NA                                | NA               | NA             |
|   | <ul style="list-style-type: none"> <li>Pressurization</li> </ul>               | NA                                | NA               | NA             |
|   | d. No. of continuous staircases to terrace                                     | NA                                | NA               | NA             |
|   | e. Width of Corridor   | NA                                | NA               | NA             |
|   | f. Door Size   | 1 m                               | 1m               | MR             |
| 3   | <b>Compartmentation.</b>   |                                   |                  |                |
|   | <ul style="list-style-type: none"> <li>Fire check door</li> </ul>              | NA                                | NA               | NA             |
|   | <ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul> | NA                                | NA               | NA             |
|   | <ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>    | NA                                | NA               | NA             |
|   | <ul style="list-style-type: none"> <li>Water Curtain</li> </ul>                | NA                                | NA               | NA             |
|   | <ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>                 | NA                                | NA               | NA             |
| 4   | <b>Smoke Management System.</b>  |                                   |                  |                |
|   | <ul style="list-style-type: none"> <li>Basements</li> </ul>                    | 12 a/c per hour                   | NA               | NA             |
|   | <ul style="list-style-type: none"> <li>Upper floors</li> </ul>                 | 12 a/c per hour                   | NA               | NA             |

|    |  |            |           |     |
|----|--|------------|-----------|-----|
| 5  | <b>Fire Extinguishers</b>  |            |           |     |
|    | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>  | 03nos      | 06nos     | MR  |
|    |  | ABC/CO2    | ABC-06nos | MR  |
|    |  | ISI Marked | Yes       | MR  |
| 6  | <b>First-Aid Hose Reels.</b>   |            |           |     |
|    | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>   | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
| 7  | <b>Automatic fire detection and alarming system.</b>   |            |           |     |
|    | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
| 8  | <b>MOEFA</b>   | NA         | NA        | NA  |
| 9  | <b>Public Address System.</b>  | NA         | NA        | NA  |
| 10 | <b>Automatic Sprinkler System.</b>   |            |           |     |
|    | <ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>   | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
| 11 | <b>Internal Hydrants</b>   |            |           |     |
|    | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>   | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
| 12 | <b>Yard Hydrants.</b>  |            |           |     |
|    | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>   | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
| 13 | <b>Pumping Arrangements</b>  |            |           |     |
|    | <ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> </ul> </li> </ul> |            |           |     |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | N/A        | N/A       | N/A |
|    |  | NA         | NA        | NA  |
|    |  | NA         | NA        | NA  |
|    | NA   | NA         | NA        |     |

|     |  |     |     |     |
|-----|--|-----|-----|-----|
| 14  | <b>Captive Water Storage for fire fighting.</b>                          |     |     |     |
|     | • Underground tank capacity  | NA  | NA  | NA  |
|     | ➤ Draw-off connection  | NA  | NA  | NA  |
|     | ➤ Fire service inlet   | NA  | NA  | NA  |
|     | ➤ Access to tank   | NA  | NA  | NA  |
|     | • Overhead Tank capacity   | NA  | NA  | NA  |
| 15  | <b>Exit Signage.</b>   |     |     |     |
| NA  | NA   | NA  | NA  |     |
| 16  | <b>Provision of Lifts.</b>   |     |     |     |
|     | • Pressurization of Lift Shaft   | N/A | N/A | N/A |
|     | • Pressurization of Lift lobby   | N/A | N/A | N/A |
|     | • Communication In lift Car  | N/A | N/A | N/A |
|     | • Fireman's Grounding Switch   | N/A | N/A | N/A |
|     | • Lift Signage   | N/A | N/A | N/A |
| 17  | <b>Standby power supply</b>  |     |     |     |
| N/A | N/A  | N/A | N/A |     |
| 18  | <b>Refuge Area.</b>  |     |     |     |
|     | ➤ Total Area   | N/A | N/A | N/A |
|     | ➤ Location   | N/A | N/A | N/A |
| 19  | <b>Fire Control Room</b>   |     |     |     |
|     | • Detector System Panel  | N/A | N/A | N/A |
|     | • Flow Switch Panel  | N/A | N/A | N/A |
|     | • PA System Panel  | N/A | N/A | N/A |
|     | • Batter backup  | N/A | N/A | N/A |
|     | • Building Floor Plans   | N/A | N/A | N/A |
| 20  | Special Fire Protection Systems for Protection of special Risks, if any: |     |     |     |
| N/A | N/A  | N/A | N/A |     |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to grant of fire safety certificate issued vide this department letter of even no. 1468 dated 09.10.2017.

DO (RM)  
 13/04/2021  
 Dy CEO (02) - Home quarantine  
 Director  
 15/04/21  
 O/A/ATC

Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation:- ADO/RN

13/04/2021  
 15/04/21