

E-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/MN/2021/ 105

Dated: 20/04/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s. Hira Sweets & Confectionary Private Limited located at Ground floor H. N. A-2, Kirti Nagar, New Delhi 110015 in a building comprised of Basement, Ground & three upper floors Owned/Occupied by M/s. Hira Sweets & Confectionary Private Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and verified by the officer concerned of this department on 02-04-2021 in the presence of Sh. Kunj Bihari Aggarwal (Manager) and found that the said building is fit for occupancy class " Assembly" Group D (Ground floor Only) with effect from 20/04/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/04/2021 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. M/s. Hira Sweets & Confectionary Private Limited located at H. N. A-2, Ground Floor, Upper basement, Kirti Nagar New Delhi
2. Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027.

ok
19/04/2021

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. This NOC is valid for Ground floor only.

1. Name & address of the building : M/s. Hira Sweet & Confectionary Private Limited
Located at H. N. A-2, Ground Floor, Upper
Basement, Kirti Nagar, New Delhi-110015.
2. Type of Occupancy : Assembly
3. Type of Case : New
4. Details of previous NOC Letter no. : Nil
5. Fire Safety directives Letter No. : N.A.
6. Date of inspection : 05/04/2021
7. Name of the Inspecting Officer : Sarabjeet Singh ADO (MN)
8. Name and designation of Officer
From the building side : Sh. Kunj Bihari Aggarwal (Manager)
9. Year of Construction : 2010
10. Applicant's email letter No : Online application ID. No. 2021031011169 dated
10/03/2021

The Restaurant is running at Ground Floor in a Building comprised of Basement + Ground + Three Upper Floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mts	Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA (G.F.)	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA (G.F.)	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m X 1.5m	Provided (2m & 1.60m)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4, ABC & CO ₂	Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking		Provided	MR

	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System:			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	NA	Provided	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	Provided	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	1 No.	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	1 No.	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NR	NR	NR
	<ul style="list-style-type: none"> Hose Box 	NR	NR	NR
13	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	Required	Provided	MR
14	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw off connection 	NA	Provided	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	Provided	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	Provided	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 liters	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts:			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Lift Signage 	NA	NA	NA
17	Standby power supply	Required	Provided	MR

N/4

	➤ Location	NA	NA	NA
1	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
12/4/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

98/ADO/MN
09/04/2021

[Signature]
~~ADO (MN)~~

[Signature]
12/04/2021

[Signature]
DCFO (S2) 16/4/21

C.F.O.

[Signature]
16/4

[Signature]
16/04/2021

FTPS

D.O. (WEST) 97
DATED. 12/04/21



Sir, F.T alongwith correction is put up for your perusal & sig. pls. *[Signature]*