

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No. F.6/DFS/MS/EH/SZ/2021/ 184

Dated. 16/04/2021

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Pind Balluchi – Grills & Platters ( A Unit of Classic Hospitality)** running at **ground floor of the building** comprised of Basement, Stilt, Ground + Three Upper Floors located at A-3, Pamposh Enclave, Greater Kailash-1 (TE Hotel), New Delhi 110048 was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2017/SZ/1652 dated 16/11/2017. The restaurant premise was re-inspected by the officer concerned of this department on 02/04/2021 in the presence of Sh. Shakti of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D “Assembly Building”** Restaurant as above with effect from 16/04/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/04/2021 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, Central Zone, Lajpat Nagar, Delhi-24.
2. M/s Pind Balluchi – Grills & Platters (A Unit of Classic Hospitality) at ground floor of at A-3, Pamposh Enclave, Greater Kailash-1 (TE Hotel), New Delhi 110048

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.”

2	Type of Occupancy	Group-D Assembly Building.
3	Building Comprised of	Basement, Stilt, Ground + Three upper floors
4	Type of Case	Renewal
5	Details of Previous NOC	F.6/DFS/MS/EH/2017/SZ/1652 dated 16/11/2017
6	Fire Safety Directives Letter No	Nil
7	Date of Inspection	02/04/2021
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)
9	Name & Designation of Officers from the building side	Mr. Shakti
10	Year of construction	----- Restt. at ground floor of the bldg.
11	Applicant letter No.	Online No. 2020120508840 dated 30/12/2020

S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	Required	9m	MR
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	N/A	N/A	N/A
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors.</li> </ul>	Required	02 Nos	MR
	<ul style="list-style-type: none"> <li>Basement floor.</li> </ul>	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	1.28 & 1.50 m (Stilt to GF)	MR (old case)
	<ul style="list-style-type: none"> <li>Basement floor</li> </ul>	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	Required	2 mtr & 1.50 mtr	MR
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire rating of shaft door.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Water curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire dampers.</li> </ul>	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	30 ACPH	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 ACPH	N/A	N/A
<b>5</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	06 Nos	06 Nos	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>ISI Marking</li> </ul>	ISI marked	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> </ul>	One	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5mm	Provided	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			

	<ul style="list-style-type: none"> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	Provided	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground floor.</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	Required	100 mm	MR
		Required	One	MR
		Required	One	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	450 LPM	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 Ltrs	10,000 ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

N/20

	<ul style="list-style-type: none"> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2017/SZ/1652 dated 16/11/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Sh. Rajesh Kumar*  
5/4/2021

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Designation: ADO (BCP)

~~DO (SD)~~

*ADP*  
06/04

DFA (S) F.T. please.  
*Sh.*

~~ADO (BIP)~~

As approved, F.T. letter is put up for your signature pl

1/14  
12/14/2021

By C/O S/2 *Sh.*

M.S. U/S