

c-66

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/WZ/ 355

Dated: 4/5/21

FIRE SAFETY CERTIFICATE

Certified that **The Sovereign School, Pkt-17, Phase-III, Sector-24, Rohini, Delhi-85**, comprised of **Basement + Ground + Four upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/1381 dated 13.06.2018**. The premises was re-inspected by the officer concerned of this department on **08.04.2021** in the presence of **Mr. R. N. Jindal (Chairman)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Rule 33 of the Delhi Fire Service Rules, 2010 and the building premises is fit for occupancy of **Group Class B (Educational)** with effect from 4/5/21 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 4/5/21..... at New Delhi by


(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54
2. The Principal, The Sovereign School, Pkt-17, Phase-III, Sector-24, Rohini, Delhi-85.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : The Sovereign School, Pkt-17, Phase-III, Sector-24, Rohini, Delhi-85
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Basement + Gr. + 04 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2018/1381 dated 13.06.2018
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2007/3193 dated 25.10.2007
6. Date of inspection : 08.04.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. R. N. Jindal (Chairman)
9. Year of Construction : 2007
10. Applicant's letter No. : Online e-mail dated 23.03.2021.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Rule 35(6) | Provided at site | Remarks MR/NMR |
|--------|---|--|--|--|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <ul style="list-style-type: none"> Accessible Accessible NA | <ul style="list-style-type: none"> Accessible Provided NA | <ul style="list-style-type: none"> MR MR NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | <ul style="list-style-type: none"> 04 04 | <ul style="list-style-type: none"> 04 04 | <ul style="list-style-type: none"> MR MR |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | <ul style="list-style-type: none"> 1.5m 1.5m | <ul style="list-style-type: none"> Provided Provided | <ul style="list-style-type: none"> MR MR |
| | c. Protection of exits | | | |
| | Fire check door | | | |
| | <ul style="list-style-type: none"> • Pressurization | <ul style="list-style-type: none"> NA NA | <ul style="list-style-type: none"> NA NA | <ul style="list-style-type: none"> NA NA |
| | d. No. of continuous staircases to terrace | <ul style="list-style-type: none"> 01 | <ul style="list-style-type: none"> 02 | <ul style="list-style-type: none"> MR |
| | e. Width of Corridor | <ul style="list-style-type: none"> NA | <ul style="list-style-type: none"> NA | <ul style="list-style-type: none"> NA |
| | f. Door Size | <ul style="list-style-type: none"> Required | <ul style="list-style-type: none"> Provided | <ul style="list-style-type: none"> MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <ul style="list-style-type: none"> NA Required Required NA Required | <ul style="list-style-type: none"> NA Provided Provided NA Provided | <ul style="list-style-type: none"> NA MR MR NA MR |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | <ul style="list-style-type: none"> 30 a/c per hour 12 a/c per hour | <ul style="list-style-type: none"> Exhaust fan provided Natural ventilation | <ul style="list-style-type: none"> MR MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | <ul style="list-style-type: none"> 40 ABC/CO2 ISI marked | <ul style="list-style-type: none"> 40 ABC/CO2/Wco2 Yes | <ul style="list-style-type: none"> MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | <ul style="list-style-type: none"> 03 30mm 5m | <ul style="list-style-type: none"> Provided Provided Provided | <ul style="list-style-type: none"> MR MR MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | <ul style="list-style-type: none"> NA NA NA NA NA | <ul style="list-style-type: none"> NA NA NA NA NA | <ul style="list-style-type: none"> NA NA NA NA NA |

| | | | | |
|-----|---|-----------|-----------|----|
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> • Basement • Ground & Upper Floors • Sprinkler above false ceiling | Required | Provided | MR |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | 100mm | Provided | MR |
| | | 03 | Provided | MR |
| | | 03 | Provided | MR |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants • Hose Box | NA | Provided | NA |
| | | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 180lpm | 180lpm | MR |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | <ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | 900lpm | 900lpm | MR |
| | | 40m | 40m | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | 75,000ltr | 75,000ltr | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | 25,000ltr | 25,000ltr | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | NA | NA | NA |
| | | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

2/18

| | | | | |
|-----|---|----|----|----|
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |
|-----|---|----|----|----|

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2018/1381 dated 13.06.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
13/4/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Ajay
16/04/2021

Dy CPO (S2 & W2)

[Signature]
19/4

CFO

[Signature]
20/4

~~*[Signature]*
23/04/2021~~

AD of A-K S / Rohini

FT letter is put up for kind perusal and signature please.

