

C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2021/ 377

Dated: 12/5/2021

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Sec. School Located at D-Block, Ashok Vihar, Phase-1, Delhi-110052**, consists of two three blocks namely Old Block & New Blocks, Old Block comprised of Ground + 02 Upper Floors & New Two Blocks Ground + 01 Upper Floor each owned/ occupied by Govt. Girls Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with **D.O.E. Circular no.3298-3398 dated 01-03-2011 issued by the GNCT of Delhi** and verified by the officer concerned of this department on **09.04.2021** in the presence of **Ms. Jyoti Bhatia (Vice-Principal)** and that the said building is fit for occupancy "Educational Building" Group B with effect from 12/5/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...12/5/21..... at New Delhi by.


(Atul Garg)
Director


Copy to:-

1. The Director, Directorate of Education, GNCT NCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Girls Sr. Sec. School, D-Block, Ashok Vihar, Phase-1, Delhi-110052.

CONDITIONS

1. **The Management shall apply NOC for MP Hall separately.**
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

| | | | | |
|---------------|--|--|--|-------------------------|
| 1 | Name & address of the building | Govt. Girls Sr. Sec. School Located at D-Block, Ashok Vihar, Phase-1, New Delhi-110052 | | |
| 2 | Type of Occupancy | Educational Building "B" "Old Block (Ground Plus Two Upper Floors & New Two Blocks (Ground Plus One upper floor) | | |
| 3 | Type of case | New | | |
| 4 | Details of previous NOC | Nil | | |
| 5 | Fire safety directives letter No | D.O.E Education Cir. No. 3298-3398 dated 1.3.2011 | | |
| 6 | Date of inspection | 09.04.2021 | | |
| 7 | Name of the inspecting Officers | S.P. Bhardwaj, ADO (WP) | | |
| 8 | Name and designation of officers from the building side | Ms. Jyoti Bhatia (Vice Principal) | | |
| 9 | Year of construction | Old Block 1980, New Blocks 2015 | | |
| 10 | Applicant's letter No. | Email dated 25.03.2021 | | |
| S. NO. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/D.O.E Cir. No. 3298-3398 dated 01.03.2011 | Provided at site | Remarks MR / NMR |
| 1 | Access to building | | | |
| | 1) Road width | 6 Mtrs. | Provided | MR |
| | 2) Gate width | 4.5 Mtrs. | 5 Mtrs. | MR |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2 | Number, width Type & arrangement of exits | | | |
| | a. Number of staircases | | | |
| | 1. Upper floors | Old Block-02 Nos. & New Blocks-01 each block | Old Building=03 & New Blocks=01 each block | MR |
| | 2. basements | N/A | N/A | N/A |
| | b. Width of staircase | | | |
| | 1. Upper floors | 1.5 Mtrs. if less than 1.5 Mtrs., addition staircase of 0.75 Mtrs. is required | Old Block=1x1.6 m & 2 x 1.25 m & New Blocks=1x1.5 m each block | MR |
| | 2. basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircase to terrace | One each Block | Provided | MR |
| | e. Width of corridor | 1.5 Mtrs. | Provided | MR |
| | f. Door size | 1 Mtrs | 1.20 Mtrs (Two Each Room) | MR |
| 3 | Compartmentation. | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Sealing of electrical shafts | N/A | N/A | N/A |
| | 3. Fire Rating of shaft door | N/A | N/A | N/A |
| | 4. water curtain | N/A | N/A | N/A |
| | 5. Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | basement | 30 a/c per hour 12 a/c per hour | N/A | N/A |
| | upper floors | | Natural Ventilation | MR |

| | | | | |
|----|---|---------------|-----------------------------------|-----|
| 5 | Fire Extinguishers | | | |
| | total numbers | 27 Nos. | 31 Nos. | MR |
| | Types | CO2 & ABC | CO2 & ABC | MR |
| | ISI marking | ISI Marked | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | total numbers on each floor | 02 each floor | G & F=03 Nos. & 2nd floor=02 Nos. | MR |
| | Length of Hose reel hose | 30 m | Provided | MR |
| | Nozzle Diameter | 5 mm | Provided | MR |
| 7 | Automatic fire detection and alarming system | | | |
| | Type of detectors | N/A | N/A | N/A |
| | location of Main Panel | N/A | N/A | N/A |
| | location of Repeater panel | N/A | N/A | N/A |
| | Alternate source of power | N/A | N/A | N/A |
| | hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | N/A | N/A |
| 9 | Public Address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | basement | N/A | N/A | N/A |
| | upper floors | N/A | N/A | N/A |
| | sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | Size of riser/down-corner | N/A | N/A | N/A |
| | Number of Hydrants per floor | N/A | N/A | N/A |
| | hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | total number of hydrants | N/A | N/A | N/A |
| | hose box | N/A | N/A | N/A |
| 13 | Pumping arrangements | | | |
| | 1. Ground level | | | |
| | a. Discharge of main Pump | N/A | N/A | N/A |
| | b. Head of main pump | N/A | N/A | N/A |
| | c. Number of main pumps | N/A | N/A | N/A |
| | d. jockey pump out put | N/A | N/A | N/A |
| | e. jockey pump head | N/A | N/A | N/A |
| | f. Standby Pump output | N/A | N/A | N/A |
| | g. Stanby Pump head | N/A | N/A | N/A |
| | h. Auto Starting/Manual stopping | N/A | N/A | N/A |
| | pump house access | N/A | N/A | N/A |
| | 2. Terrace level | | | |
| | a. Discharge of pump | 450 LPM | Provided (2 Nos.) | MR |
| | b. head of the pump | 40 Mtrs. | Provided | MR |
| | c. Power supply | Required | Provided | MR |
| | d. Auto starting of pump | Required | Provided | MR |
| 14 | Captive water storage for fire fighting | | | |
| | 1. Underground tank capacity | N/A | N/A | N/A |
| | a. Draw-off connection | N/A | N/A | N/A |
| | b. fire service inlet | N/A | N/A | N/A |
| | c. Access to tank | N/A | N/A | N/A |
| | Over head tank Capacity | 10,000 | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |

217

| | | | | |
|----|---|--------------|--|-----|
| 16 | Provision of lifts. | | | |
| | a. Pressurization of lift shaft | N/A | N/A | N/A |
| | b. pressurization of lift lobby | N/A | N/A | N/A |
| | c. communication in lift car | N/A | N/A | N/A |
| | d. Fireman's grounding switch | N/A | N/A | N/A |
| | e. Lift signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | Not Required | | |
| | total area | N/A | N/A | N/A |
| | location | N/A | N/A | N/A |
| 19 | Fire control room | | | |
| | a. detector system Panel | N/A | N/A | N/A |
| | b. Flow switch Panel | N/A | N/A | N/A |
| | c. PA system Panel | N/A | N/A | N/A |
| | d. Batter backup | N/A | N/A | N/A |
| | e. Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special risks, if any: | Required | CO2 Fire Extinguisher Provided near Electrical Panel | MR |

The fire protection systems provided in the building were checked and found functional at the time of Inspection

Note:- MP Hall is under renovation Management shall apply separately for NOC after renovation.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirement under the rules, grant of Fire Safety Certificate is recommended under rules 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007

Accordingly DFA is put up for your approval and signature please.

[Signature]
SP Bhardwaj ADO (WP)



[Signature]

[Signature]
09/04/2021

[Signature]
DFO (W2)

[Signature]
07/5/2021

[Signature]

[Signature]
4/5

FI R/S

[Signature]
08/03/20

[Signature]

[Signature]
06/05
ADD (WP)