

C-34

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2021/ 327

Dated: 6/04/2021

FIRE SAFETY CERTIFICATE

Certified that the Building Govt. Girls Sr. Sec. School, Located at Dichaon Kalan, New Delhi-110043. (School.ID.1822050) comprised of four blocks namely A -Block, B- Block, C- Block & D- Block. Each block is having **Ground + One Upper Floor** only owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2018/SZ/758 Dated 20/04/2018. The premises was re inspected by the officer concerned of this department on 05/04/2021 in the presence of Smt. Bimla Devi (HOS). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of **three years**, subject to compliance of the condition given below.

Issued on ..1.6.21... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Govt. Girls Sr. Sec. School, Located at Dichaon Kalan, New Delhi-110043. (School.ID.1822050)
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

H-19

INSPECTION REPORT

1. Name & address of the building: Govt. Girls Sr. Sec. School, Located at Dichaon Kalan, New Delhi-110043. (S. ID.1822050)
2. Type of Occupancy : Educational Four Blocks(Ground +One Upper Floors Only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/758 Dated 20/04/2018
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 05-04-2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side :Smt. Bimla Devi (HOS)
9. Year of Construction : 2009&2014
10. Applicant's letter No. :Email dated 18/03/2021

No. of Students=271
No. of class rooms=20
Plot area=6458.38 sqm ²
Covered area=840 sqm ²

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 20/04/2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 mtr 4.5 mtr NA 	<ul style="list-style-type: none"> 12 m Provided 470cm NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> 01 no. in each block NA 150cm in A,C & D block &150 cm/additional staircase of 75cms if less then 150cms in B block NA NA 100cm 100cm 	<ul style="list-style-type: none"> 1no. in A, C & D block & 02 no. in B block NA BL-A, C,D=150cm & BL-B=140cm &144cm NA NA 150cm 100cm (Double door) 	<ul style="list-style-type: none"> MR NA MR(Old Case) NA NA NA MR Old Case MR old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/758 Dated 20/04/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Pr Singh*
 Designation *AD/DCR*

16/5/21
DO/SD - on leave

Bye Bye

[Signature]

F.T.