

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 338

Dated: 20 / 04 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that **Indian Modern School**, located at **Chattarpur, Enclave- II, New Delhi-110074** comprised of **Ground plus Three Upper Floor** owned/occupied by **New Parvati Education Society** was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/1815 Dated 15/12/2017. The said premises was re-inspected by officer concerned of this department on 09/04/2021 in presence of Ms. Sushma Sharma (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 20 / 04 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 20/04/2021 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Principal, Indian Modern School, at Chattarpur, Enclave- II, New Delhi-74
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54


**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	Indian Modern School, C- Block, Chattar Pur, Enclave II, New Delhi 110074		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2017/SZ/1815 Dated 15/12/2017		
6	Fire Safety Directives Letter No	BBL / NBC requirements		
7	Date of inspection	09/04/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Sushma Sharma (Principal)		
10	Year of construction	2004 & 2014		
11	Applicant letter No.	Gmail dated 01/02/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC requirements	Provided at Site	Remarks MR/NMR
1.	<b>Access to Building.</b>			
	• Road width	Required	6 mtr	MR
	• Gate width	-NA-	Directly accessible	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	01 Nos	02	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	1.50m & 0.86 m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	02 Nos	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	-NA-	-NA-	-NA-
3.	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	14 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7.	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Number of Hydrant per floor</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Overhead tank capacity.</li> </ul>	10,000 Ltrs	10,000 Ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Pressurization of lift lobby.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Communication in lift car.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Fireman's switch.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Location</li> </ul>	-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-


	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-
<p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2017/SZ/1815 Dated 15/12/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <div style="text-align: right;">         Signature of the Inspecting Officer        Name: Sh. Rajesh Kumar        Design: ADO (BCP)     </div>				

~~DO (SD)~~

13/04

ET

DFO(S2)



ADO BCP

As approved, F.T. letter is put up for your signature pl.

19/04/2021

Dy Cfo/S2



M.S.UL