

C-57

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2021/ 375

Dated: 10/5/2021

FIRE SAFETY CERTIFICATE

Certified that the KIIT World School (New State Academy Sr. Secondary School), Located at Zone H-4, Pitampura, Delhi-110034, consists of Two Blocks : BL-1 comprised of Ground + 03 Upper Floors & BL-2 comprised of Ground Floor only were issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2018/394 dated 12.03.2018 & F6/DFS/MS/SCHOOL/2018/1020 Dated 10.05.2018 respectively. The said premises were re inspected by the officer concerned of this department on 06.04.2021 in the presence of Dr. Sangeeta Bhatia (Vice-Principal) & Ms. Richa Verma (Head Mistress) and found that the premises / buildings have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and found that the premises/building is fit for occupancy "Educational" Group B with effect from 10/5/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/5/21 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, KIIT World School, Zone H-4, Pitampura, New Delhi-110034.

CONDITIONS

1. A Porta Cabin on Terrace shall not be used for School Activities, else FSC shall be null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1. Name & address of the building: KIIT World School Located at Zone H-4, Pitampura, Delhi-110034
2. Type of Occupancy : Educational Building,
3. Type of Case : Renewal Two Blocks, BL-1=(Ground + 03 Upper Floors) & BL-2=Ground Floor only
4. Details of previous NOC : **BL-1** : F6/DFS/MS/School/WZ/2018/394 Dated 12-03-2018 & **BL-2** : F6/DFS/MS/SCHOOL/2018/1020 Dated 10.05.2018
5. Fire Safety directives Letter No. : D.O.E Circular 262-362 Dated 17/01/2005
6. Date of inspection : 06.04.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
from the building side : Dr. Sangita Bhatia (Principal) & Ms. Richa Verma (Head Mistress)
9. Year of Construction : 1992
10. Applicant's letter No. : email dated 25.03.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. 262-362 Dated 17/01/2005/letter dated 12.03.2018 & 10.05.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 370cm NA 	<ul style="list-style-type: none"> MR MR(Old Case) NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> BL-1 Block Nos. NA 	<ul style="list-style-type: none"> 3 Nos. NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> 2x152cm & 1x132cm (include railing) NA 	<ul style="list-style-type: none"> MR Old case NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	236 cms.	NA
	f. Door Size	1 mtrs	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Tynes 	<ul style="list-style-type: none"> 22 nos. ABC & CO₂ 	<ul style="list-style-type: none"> Provided Provided 	<ul style="list-style-type: none"> MR MR

	<ul style="list-style-type: none"> Total numbers on each floor 	BL-Block: 2 Nos.	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	Required in BL-Block	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	Required in BL-Block	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of main pump 	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	➤ Discharge of pump	BL-Block: 900 lpm & 180 Lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting: BL-Block			
	<ul style="list-style-type: none"> Underground tank capacity 	20,000 ltrs	provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts BL-Block			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 fire extinguisher near electrical Panel	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- A Porta Cabin at Terrace of BL-1 Block have been sealed for school activities made for installation of Solar Panel (Undertaking).

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. BL-1: F6/DFS/MS/School/WZ/2018/394 Dated 12-03-2018 & BL-2: F6/DFS/MS/SCHOOL/2018/1020 Dated 10.05.2018 is recommended under rules 37 of the Delhi Fire Service Rules 2010 & DFS Act 2007.

~~D.O. West~~

S.P. Bhardwaj
ADO (WP) 9/4/21

D.O. (WEST)/...120
DATED...12/04/21

~~D.O. West~~
12/04/2021

~~DCFO (W2)~~

~~[Signature]~~
8/5/2021

~~ADO West~~

AT to put up for Pirmal pu
~~[Signature]~~
19/5/2021

~~D.O. WZ~~

~~[Signature]~~
7/5/21

~~MS/ WZ~~